

1100 Air Quality Management Section

1124 Control of Volatile Organic Compound Emissions

(As Distributed in Review Committee Meeting 5 on June 25, 2014)

36.0 Vapor Control at Gasoline Dispensing Facilities

xx/11/2014

36.1 Applicability

36.1.1 The provisions of 36.0 of this regulation apply to any gasoline dispensing facility located in the State of Delaware, except:

36.1.1.1 Any gasoline dispensing facility, which never has a monthly throughput of greater than 10,000 gallons of gasoline, shall be subject only to the requirements of 36.7.2 of this regulation. Any gasoline dispensing facility that ever exceeds this throughput shall be subject to all of the requirements of 36.0 of this regulation, and shall remain subject to these requirements even if its throughput later falls below the exemption throughput.

36.1.1.2 Any gasoline dispensing facility that is used exclusively for refueling marine vehicles, aircraft, farm equipment, or emergency vehicles.

36.1.2 The requirements of 36.8 of this regulation apply to any owner or operator of any company that performs compliance testing at gasoline dispensing facilities within the State of Delaware.

36.1.3 The requirements of 36.0 of this regulation are in addition to all other State and Federal requirements, to include the permitting requirements of 7 **DE Admin. Code** 1102. Any gasoline dispensing facility that is currently subject to any State or Federal rule by exceeding an applicability threshold is and shall remain subject to those provisions.

36.1.4 Compliance Schedule

Any gasoline dispensing facility subject to the requirements of 36.0 of this regulation shall be in compliance as follows:

36.1.4.1 Any new or reconstructed gasoline dispensing facility that first commences construction prior to (insert the effective date of this regulation), shall comply with 36.3 and all other applicable requirements of this regulation.

36.1.4.2 Any new or reconstructed gasoline dispensing facility that first commences construction on or after (insert the effective date of this regulation) shall comply with 36.4 and all other applicable requirements of this regulation.

36.2 Definitions

Terms being defined in 36.2 of this regulation are used exclusively for 36.0 of this regulation. Other terms not defined herein shall have meanings defined in the Clean Air Act Amendments of 1990 (CAA), 7 DE Admin Code 1101, or 2.0 of this regulation.

“Assist System” means a system that creates a vacuum to assist the movement of gasoline vapors in the vehicle tank back into the storage tank.

“Balance System” means a system where pressure develops in the vehicle tank during fueling operations, and vacuum in the storage tank created when the fuel is removed, forces displaced vapors out the vehicle tank and back into the storage tank.

“New Facility” means a facility that is located on a site that has not previously served as a gasoline dispensing facility.

“Pressure/Vacuum Valve” or “P/V Valve” means a relief valve installed on the vent stack of a tank system that is designed to open at specific pressure and vacuum settings to protect the system from excessive pressure or vacuum.

“Reconstructed Facility” means a facility that is located on a site that has previously served as a gasoline dispensing facility and removes all tanks, dispensers, and piping as part of reconstruction.

“Tank System” means a storage tank or a set of manifolded storage tanks containing gasoline.

“Ullage” means the empty volume of a gasoline storage tank system that contains liquid gasoline. Ullage is expressed as accumulated gallons of empty volume for all of the gasoline storage tanks in a manifolded system.

36.3 Standards for Facilities with Stage II Vapor Recovery Systems

36.3.1 The owner or operator of any gasoline dispensing facility identified in 36.1.4.1 of this regulation shall:

36.3.1.1 Design, install, operate, and maintain one of the Stage II Vapor Recovery Systems identified in 36.9 of this regulation.

36.3.1.2 For systems with manifolded vapor lines, the liquid shall return into the lowest octane tank. For non-manifolded systems with separate vapor lines, the liquid shall return to the tank that has the same product as is dispensed at the nozzle where the liquid was introduced into the vapor lines.

36.3.1.3 Install and maintain a vapor shear valve that functions similarly to the product shear valve.

36.3.1.4 Conspicuously post "Operating Instructions" on both sides of each gasoline dispenser. Such instructions shall include:

36.3.1.4.1 A clear description of how to correctly dispense gasoline.

36.3.1.4.2 A warning that repeated attempts to continue dispensing gasoline, after the system has indicated that the vehicle fuel tank is full (by automatically shutting off), may result in spillage or recirculation of gasoline.

36.3.1.4.3 A toll-free telephone number to report problems experienced with the vapor recovery system to the Department.

- 36.3.2 At least one representative (an owner, facility manager, or designated employee) from each facility, or facilities under common ownership, shall attend a training program on the operation and maintenance requirements of the Stage II equipment that is selected for installation or installed on their facility premises. Acceptable forms of training include equipment manufacturer's seminars, classes or workshops, or any other training approved by the Department.
- 36.3.2.1 Verification, such as a certificate of attendance from the training program, shall be obtained by the attendee within three months of the installation of the Stage II system. The certificate shall display the name of the person who completed the training program.
- 36.3.2.2 The representative that completed the training program is then responsible for informing all facility employees about conducting routine maintenance pursuant to 36.3.3 of this regulation and about the operation and maintenance of the Stage II system. The representative shall maintain proof of training for all employees who will be conducting daily inspections. If such representative leaves that facility, or the company owning several facilities, another representative shall take and successfully complete the training within three months.
- 36.3.2.3 Training shall include, but not be limited to, the following subjects:
- 36.3.2.3.1 Purposes and effects of the Stage II Vapor Control Program.
 - 36.3.2.3.2 Equipment operation and function specific to their facility's equipment.
 - 36.3.2.3.3 Maintenance schedules and requirements for the facility's equipment.
 - 36.3.2.3.4 Equipment warranties.
 - 36.3.2.3.5 Equipment manufacturer contracts (names, addresses, and phone numbers) for parts and service.
- 36.3.3 Each day personnel trained pursuant to 36.3.2 of this regulation shall perform routine maintenance inspections and record the inspection results.
- 36.3.3.1 Such inspections shall consist of, but not limited to, inspection of the Stage II system for the following defects:
- 36.3.3.1.1 A faceplate or face cone of a balance or assist system nozzle that does not make a good seal with a vehicle fill tube, or the accumulated damage to the faceplate or face cone is over 25% of its' surface.
 - 36.3.3.1.2 A vapor assist system nozzle fitted with an efficiency compliance device that is damaged over 25% of its' surface.
 - 36.3.3.1.3 A nozzle bellows with a triangular tear measuring ½ inch or more to a side, a hole measuring ½ inch or more in diameter, or a slit or tear measuring one inch or more in length.
 - 36.3.3.1.4 A nozzle bellows or efficiency compliance device that is loosely attached to the nozzle body, not attached by a manufacturer approved method, or a vapor check valve frozen in the open position.

- 36.3.3.1.5 A nozzle liquid shutoff mechanism that malfunctions in any manner, where the spring or latching knurl is damaged or missing.
- 36.3.3.1.6 A nozzle with a vapor check valve that is defective, or a hose with a disconnected or damaged breakaway.
- 36.3.3.1.7 A vapor assist system nozzle spout that is damaged and the vapor collection holes are obstructed.
- 36.3.3.1.8 A dispenser mounted vacuum pump that is not functioning.
- 36.3.3.1.9 A vacuum assist system with a central vacuum unit or vapor processing unit that is inoperative.
- 36.3.3.1.10 A hose retractor that does not fully retract.
- 36.3.3.1.11 Any other component required by the Department for use in the system that is missing, disconnected, or malfunctioning.
- 36.3.3.2 The owner or operator shall post "Out of Order" signs and "Bag-out" the nozzle associated with any part of the defective vapor recovery system until said system has been repaired or replaced.

36.4 Standards for Facilities Without Stage II Vapor Recovery Systems

36.4.1 The owner or operator of any gasoline dispensing facility identified in 36.1.4.2 of this regulation shall design, install, operate, and maintain:

- 36.4.1.1 One of the Stage I systems identified in 36.9.2 of this regulation, or
- 36.4.1.2 Components of one or more Stage I systems identified in 36.9.2 of this regulation, to include, at a minimum, the components identified in Table 36-1.

Table 36-1

Stage I System Components
Spill Container
Spill Container Lid
Replacement Drain Valve
Debris Bucket
Product Adaptor
Vapor Adaptor
Riser Adaptor
Riser Support Bracket
Drop Tube Riser Clamp
Dust Cap
Pressure/Vacuum Vent Valve
Tank Gauge Port Components
Drop Tube Overfill Prevention Device

Drop Tube
Riser Offset
Double Fill Tank Riser Configuration
Tank Bottom Protector

- 36.4.2 The owner or operator of any gasoline dispensing facility identified in 36.1.4.2 of this regulation shall maintain the tank system at a leak rate less than two times the rate allowed in accordance with TP-201.3, "Determination of 2 Inch WC Static Pressure Performance of Vapor Recovery Systems of Dispensing Facilities", dated July 26, 2012, hereby incorporated by reference, demonstrated in accordance with monitoring requirements in 36.5 of this regulation.
- 36.4.3 The owner or operator of any gasoline dispensing facility identified in 36.1.4.2 of this regulation shall maintain tank system pressure below the positive cracking pressure of the p/v valve at least 95% of the time, demonstrated in accordance with monitoring requirements in 36.5 of this regulation.
- 36.4.4 Enhanced conventional nozzles: Reserved.
- 36.4.5 Dispensing hose requirements: Reserved.
- 36.4.5 Posting and routine inspecting requirements. Any facility subject to 36.4 of this regulation shall meet the following posting, training and maintenance inspecting requirements.
- 36.4.5.1 Posting. Conspicuously post "Operating Instructions" on both sides of each gasoline dispenser. Such instructions shall include:
- 36.4.5.1.1 A clear description of how to correctly dispense gasoline.
- 36.4.5.1.2 A warning that repeated attempts to continue dispensing gasoline, after the system has indicated that the vehicle fuel tank is full (by automatically shutting off), may result in spillage.
- 36.4.5.1.3 A toll-free telephone number to report problems experienced with the gasoline dispensing system to the Department.
- 36.4.5.1.4 The owner or operator shall post "Out of Order" signs and "bag-out" the nozzle associated with any part of the defective gasoline dispensing system until said system has been repaired or replaced.
- 36.4.5.2 Routine inspecting. Each day personnel shall perform daily routine maintenance inspections and record the inspection results. Such inspections shall consist of, but not limited to, inspection of the dispensing systems for the following defects:
- 36.4.5.2.1 A nozzle liquid shutoff mechanism that malfunctions in any manner, where the spring or latching knurl is damaged or missing.
- 36.4.5.2.2 A hose with a disconnected or damaged breakaway.

36.4.5.2.3 A hose retractor that does not fully retract.

36.4.5.2.4 Any other component required by the Department for use in the dispensing system that is missing, disconnected, or malfunctioning.

36.5 Monitoring Requirements and Corrective Action

36.5.1 The owner or operator of any gasoline dispensing facility identified in 36.1.4.2 of this regulation shall design, install, operate, and maintain a continuous pressure monitoring (CPM) system as identified in Exhibit 1, Section II of CARB Executive Order VR-202-P, dated December 10, 2013, hereby incorporated by reference, to include a console with leak detection software, a vapor pressure sensor, and an automatic tank gauge, in accordance with the following:

36.5.1.1 The CPM system shall be operational a minimum of 95% of the time on a monthly basis and shall calculate and record the percentage of CPM up-time.

36.5.1.2 The CPM system shall be capable of assessing the rate of vapor leakage from the tank system at any working ullage pressure, both positive and negative.

36.5.1.3 The CPM system shall assess, on a weekly basis, the tank system leak rate and pressure profile. When the tank system leaks at a rate which is greater than the rate specified in 36.4.2 of this regulation, or when the tank system pressure is greater than the pressure specified in 36.4.3 of this regulation, then:

36.5.1.3.1 The CPM system shall activate a warning alarm, and shall record the event.

36.5.1.3.2 The owner or operator shall correct the excessive leak rate or pressure within one week of the warning alarm, reset the CPM system once the correction has been made, and the CPM system shall record the event.

36.5.1.3.3 When two consecutive failed assessments occur without corrective action, the CPM system shall activate a failure alarm, which will constitute a violation.

36.5.1.3.4 Following a corrective action, the CPM system shall recommence monitoring the tank system. If after one week the tank system again fails to meet the requirements of 36.4 of this regulation this constitutes a second warning. A third consecutive warning after a second corrective action attempt constitutes a violation.

36.5.1.3.4.1 Within two weeks of the violation the owner or operator shall develop and submit to the Department and EPA a resolution plan, which may be based on the repair of existing components, the installation of a higher crack point p/v valve, a pressure management system, or any other strategy approved by the Department and EPA, and

36.5.1.3.4.2 Upon approval of the plan by the Department, the owner or operator shall perform necessary repairs or upgrades as approved in the resolution plan, and demonstrate to the Department that all requirements of 36.4 are met.

36.6 Testing Requirements

36.6.1 Any gasoline dispensing facility subject to the requirements of 36.3 of this regulation shall perform and pass the following tests in accordance with the test methods and procedures

stated, or as otherwise approved by the Department and the Administrator of the EPA. Where any of the following test methods and procedures, in the opinion of the Department, conflict or are redundant with those specified in any CARB Executive Order adopted by reference in 36.9 of this regulation, the following test methods and procedures shall apply.

- 36.6.1.1 The following tests shall be performed and passed within 10 days of installation of the Stage II vapor recovery system:
 - 36.6.1.1.1 A Pressure Decay/Leak Test, conducted in accordance with Test Procedure TP-96-1 of the San Diego Protocol, Revision III dated 3-1-96. This test procedure is hereby incorporated by reference.
 - 36.6.1.1.2 A Dynamic Backpressure and Liquid Blockage Test, conducted in accordance with the procedures in "Recommended Practices for Installation and Testing of Vapor Recovery Systems at Vehicle Fueling Sites, PEI/RP300-97", Chapter 8. This test procedure is hereby incorporated by reference.
 - 36.6.1.1.3 For assist systems, an Air to Liquid Volume Ratio Test conducted in accordance with the procedures in "Recommended Practices for Installation and Testing of Vapor Recovery Systems at Vehicle Fueling Sites, PEI/RP300-97", Chapter 9. This test procedure is hereby incorporated by reference.
 - 36.6.1.1.4 A Vapor Tie Test, conducted in accordance with Test Procedure TP-96-1 of the San Diego Protocol, Revision III dated 3-1-96. This test procedure is hereby incorporated by reference.
- 36.6.1.2 The following tests shall be performed and passed annually for each Stage II vapor recovery system according to the test procedures stated in 36.6.1.1 of this regulation:
 - 36.6.1.2.1 A Pressure Decay/Leak Test.
 - 36.6.1.2.2 For Balance Systems, A Dynamic Backpressure and Liquid Blockage Test.
 - 36.6.1.2.3 For Assist Systems, An Air to Liquid Volume Ratio Test.
- 36.6.1.3 Any additional testing required by the Department or the manufacturer shall be carried out according to the schedule stated in any permit issued pursuant to 7 **DE Admin. Code** 1102.
- 36.6.2 Any gasoline dispensing facility subject to the requirements of 36.4 of this regulation shall perform and pass the following tests in accordance with the test methods and procedures stated, or as otherwise approved by the Department and the Administrator of the EPA.
 - 36.6.2.1 The following tests shall be performed and passed within 10 days of installation of the tank and CPM systems:
 - 36.6.2.1.1 A Pressure Decay/Leak Test, conducted in accordance with Test Procedure TP-96-1 of the San Diego Protocol, Revision III dated 3-1-96. This test procedure is hereby incorporated by reference.

- 36.6.2.1.2 A Vapor Tie Test, conducted in accordance with Test Procedure TP-96-1 of the San Diego Protocol, Revision III dated 3-1-96. This test procedure is hereby incorporated by reference.
 - 36.6.2.1.3 An operability test of the CPM system in accordance with CARB Executive Order VR-202-P, dated December 10, 2013, hereby incorporated by reference.
 - 36.6.3 The Department may require the performance of any of the tests identified in 36.6.1 and 36.6.2 of this regulation at any time at the owner's expense.
 - 36.6.4 Written notification shall be submitted to the Department not less than 10 working days prior to the performance of any compliance test, unless approval by the Department is granted to the contrary.
 - 36.6.5 The owner or operator or both and test contractor shall report all test failures to the Department within 24 hours of the failure.
 - 36.6.6 The owner or operator shall submit the following to the Department within 30 days of the test date:
 - 36.6.6.1 the actual test date; and
 - 36.6.6.2 the installing or testing companies' name or names, address or addresses, and phone number or numbers; and
 - 36.6.6.3 if any corrective action was performed pursuant to 36.8.4.2 of this regulation then submit all information specified in 36.8.4 of this regulation.
- 36.7 Recordkeeping and Reporting
- 36.7.1 The owner or operator of a gasoline dispensing facility subject to the requirements of 36.0 of this regulation shall keep on the facility premises and in a form acceptable to the Department, all of the following information. This information shall be retained for at least three years from the date of record and shall be made immediately available to the Department upon request.
 - 36.7.1.1 Permits and Applications. Copies of the Stage I, Stage II and CPM system permit applications, as applicable, and the current Construction/ Operation Permits shall be permanently maintained.
 - 36.7.1.2 Installation and Testing Results. The test results shall be dated, and shall note the installing and test companies' names, addresses, and phone numbers. These records shall be kept on file until they are replaced with new test results verifying proper functioning of the Stage II or CPM system, as applicable.
 - 36.7.1.3 Maintenance Records. Any maintenance conducted on any part of the Stage I, Stage II or CPM systems shall be logged on a maintenance record. This maintenance record shall include a general part description, the date repaired or replaced, the replacement part manufacturer's information, and a description of the problem and solution.
 - 36.7.1.4 Inspection Records. A file shall be maintained of all daily inspection reports including records of daily self-inspections, and any third party inspection records.

- 36.7.1.5 The CPM system shall generate a daily report which includes the following:
 - 36.7.1.5.1 System operational time as a percentage;
 - 36.7.1.5.2 Percentage of time pressure is above atmospheric pressure;
 - 36.7.1.5.3 Percentage of time pressure is at the positive cracking pressure of the p/v valve.

- 36.7.1.6 The CPM system shall generate a monthly report which includes the following:

- 36.7.1.6.1 System operational time as a percentage;
- 36.7.1.6.2 Percentage of time pressure is above atmospheric pressure;
- 36.7.1.6.3 Percentage of time pressure is at the positive cracking pressure of the p/v valve;
- 36.7.1.6.4 Warnings, including the date and time of each warning; and
- 36.7.1.6.5 Failures, including the date and time of each failure.

- 36.7.1.7 Compliance Records. A file shall be maintained of all compliance records. This record shall include:

- 36.7.1.7.1 Any warning letters and notices of violations issued by the Department to the facility, the facility's responses and actions to the Department's warning, the facility's report of compliance to the Department after its actions, and the Department's approval of compliance.
- 36.7.1.7.2 Daily and monthly CPM reports shall be available for printing at the facility, and be made available to the Department upon request. Daily reports shall be available for printing for the previous 90 days. Monthly reports shall be available for printing for the previous 12 months.
- 36.7.1.7.3 The CPM system shall store the electronic records of the daily and monthly reports, such that the records are maintained despite loss of power to the CPM system.
- 36.7.1.7.4 Proof of attendance and completion of a training program for each person trained in accordance with 36.3.2.2 of this regulation. This does not apply to the records of an employee who is no longer in service for at least one year.

- 36.7.2 Any gasoline dispensing facility exempted from the requirements of 36.0 of this regulation pursuant to 36.1.1.1 of this regulation shall maintain records of monthly throughput, and shall furnish these records to the Department upon request. These records shall be maintained on file for a minimum of three years from the date of record.

- 36.7.3 The owner or operator, or both, of any facility containing sources subject to 36.0 of this regulation shall comply with the requirements of 5.0 of this regulation.

36.8 Compliance Testing Company Requirements

- 36.8.1 Any owner or operator, or both, of any company that performs compliance testing pursuant to 36.6.1 or 36.6.2 within the State of Delaware shall submit all of the following information to the Department, prior to performing any compliance testing within the State of Delaware:
- 36.8.1.1 The name and business mailing address of the compliance testing company owner or operator;
 - 36.8.1.2 The address and telephone number of the facility or facilities from which the daily compliance testing activities of the compliance testing company originate;
 - 36.8.1.3 A written description of the employee training systems in place at the compliance testing company to ensure required compliance tests are performed in accordance with applicable protocols and procedures.
 - 36.8.1.4 Certification by an individual who is a responsible and trained representative of the compliance testing company containing the following language verbatim:
 - 36.8.1.4.1 I certify that I personally examined and am familiar with the information contained in this document and all the attachments and that, based on my inquiry of those persons immediately responsible for obtaining the information, I believe that the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including possible fines and imprisonment; and
 - 36.8.1.4.2 Employee training systems are in place at the company to ensure compliance tests are performed in accordance with all applicable protocols and procedures; and
 - 36.8.1.4.3 I am fully authorized to make this attestation on behalf of this Compliance Testing Company.
- 36.8.2 Any company subject to the requirements of 36.8 of this regulation shall notify the Department in writing of any change to any information submitted to the Department within 14 days of the effective date of such change.
- 36.8.3 No person subject to the requirements of 36.8 of this regulation shall perform any compliance test unless said person has first been trained in accordance to applicable compliance test protocols and procedures.
- 36.8.4 Any person subject to 36.8 of this regulation shall certify to the owner or operator of the gasoline dispensing facility that each compliance test performed to meet the requirements of 36.3 and 36.4 of this regulation was performed in accordance with 36.6 of this regulation. Certification shall include:
- 36.8.4.1 The date each compliance test was first performed and the test results; and
 - 36.8.4.2 An itemized list of all corrective actions performed. This list shall include, but not be limited to, component re-installation, tightening, repair or replacement, as necessary, for the system to pass the applicable test or tests; and
 - 36.8.4.3 The date each compliance test was performed and passed; and

36.8.4.4 Certification by a responsible and trained representative or representatives of the compliance testing company containing the following language verbatim:

36.8.4.4.1 I certify that I personally examined and am familiar with the information contained in this document and all the attachments and that, based on my inquiry of those persons immediately responsible for obtaining the information, I believe that the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including possible fines and imprisonment; and

36.8.6.4.2 I am fully authorized to make this attestation on behalf of this Compliance Testing Company.

36.9 Approved Systems

The following California Air Resources Board (CARB) executive orders are hereby adopted by reference.

36.9.1 Stage II Vapor Recovery Systems

Number & Date	Description
G-70-7-AD (03/22/93)	Certification of the Hasstech Model VCP-2 and VCP 2A Phase II Vapor Recovery System.
G-70-14-AA (02/08/83)	Recertification of Red Jacket Aspirator Assist Phase II Vapor Recovery System.
G-70-17-AD (05/06/93)	Modification of Certification of the Emco Wheaton Balance Phase II Vapor Recovery System.
G-70-18-C (08/28/79)	Modification of Certification of the Shell Model 75B1 and 75B1-R3 Service Station Phase II Vapor Recovery System.
G-70-23-AC (04/29/96)	Recertification of the Exxon Balance Phase II Vapor Recovery System.
G-70-25-AA (02/08/83)	Recertification of the Atlantic Richfield Balance Phase II Vapor Recovery System.
G-70-33-AB (03/09/84)	Certification of the Modified Hirt VCS-200 Vacuum Assist Phase II Vapor Recovery System.
G-70-36-AD (09/18/92)	Modification of Certification of the OPW Balance Phase II Vapor Recovery System.
G-70-37-B (01/22/80)	Modification of the Certification of the Chevron Balance Phase II Vapor Recovery System with OPW nozzles for Service.

G-70-38-AB (12/19/90)	Recertification of the Texaco Balance Phase II Vapor Recovery System.
G-70-48-AA (02/08/83)	Recertification of the Mobil Oil Balance Phase II Vapor Recovery System.
G-70-49-AA (02/08/83)	Recertification of the Union Balance Phase II Vapor Recovery System.
G-70-52-AM (10/04/91)	Certification of Components for Red Jacket, Hirt and Balance Phase II Vapor Recovery System.
G-70-53-AA (02/08/83)	Recertification of the Chevron Balance Phase II Vapor Recovery System.
G-70-70-AC (06/23/92)	Certification of the Healy Phase II Vapor Recovery System of Service Stations.
G-70-77 (09/15/82)	Certification of the OPW Repair/Replacement Parts and Modification of the Certification of the OPW Balance Phase II Vapor Recovery System.
G-70-78 (05/20/83)	Certification of the E-Z Flo Nozzle Company Rebuilt Vapor Recovery Nozzles and Vapor Recovery Components.
G-70-101-B (11/15/85)	Certification of the E-Z Flo Model 3006 and 3007 Vapor Recovery Nozzles and Use of E-Z Flo Components with OPW Models 11 VC and 11 VE Vapor Recovery Nozzles.
G-70-107 (05/15/86)	Certification of Rainbow Petroleum Products Model RA3003, RA3005, RA3006 and RA3007 Vapor Recovery Nozzles and Vapor Recovery Components.
G-70-110 (01/20/87)	Certification of Stage I and II Vapor Recovery Systems for Methanol Fueling Facilities.
G-70-118-AB (03/31/95)	Certification of Amoco V-1 Vapor Recovery System.
G-70-125-AA (03/16/93)	Modification of the Certification of the Husky Model V Phase II Balance Vapor Recovery Nozzle.
G-70-127 (08/16/90)	Certification of the OPW Model 111-V Phase Vapor Recovery Nozzle.
G-70-134 (12/21/90)	Certification of the EZ Flo Rebuilt A-4000 Series and 11V-Series Vapor Recovery System.
G-70-139 (03/17/92)	Addition to the Certification of the Hirt Model VCS-200 Phase II Vapor Recovery System.

G-70-150-AE (07/12/00)	Modification of the Certification of the Gilbarco Vapor Vac Phase II Vapor Recovery System.
G-70-153-AD (04/03/00)	Modification to the Certification of the Dresser/Wayne WayneVac Phase II Vapor Recovery System.
G-70-154-AA (06/10/97)	Modification to the Certification of the Tokheim MaxVac Phase II Vapor Recovery System.
G-70-159-AB (07/17/95)	Modification of the Certification of the Saber Nozzle for Use with the Gilbarco VaporVac Phase II Vapor Recovery System.
G-70-163-AA (09/04/96)	Certification of the OPW VaporEZ Phase II Vapor Recovery System.
G-70-164-AA (12/10/96)	Modification to the Certification of the Hasstech VCP-3A Vacuum Assist Phase II Vapor Recovery System.
G-70-165 (04/20/95)	Healy Vacuum Assist Phase II Vapor Recovery System.
G-70-169-AA (08/11/97)	Modification to the Certification of the Franklin Electric INTELLIVAC Phase II Vapor Recovery System.
G-70-170 (02/22/96)	Certification of the EZ-flo Rebuilt 5005 and 5015 for use with the Balance Phase II Vapor Recovery System.
G-70-177-AA (06/22/00)	Certification of the VCS400-7 Vacuum Assist Phase II Vapor Recovery System.
G-70-179 (07/02/97)	Certification of the Catlow ICVN-V1 Vacuum Assist Phase II Vapor Recovery System.
G-70-180 (04/17/97)	Order Revoking Certification of the Healy Phase II Vapor Recovery Systems for Gasoline Dispensing Systems.
G-70-183 (03/04/98)	Certification of the Healy/Franklin Vacuum Assist Phase II Vapor Recovery System.
G-70-186 (10/26/98)	Certification of the Healy Model 400 ORVR Vapor Recovery System.
G-70-188 (05/18/99)	Certification of the Catlow ICVN Vapor Recovery Nozzle System for use with the Gilbarco VaporVac Vapor Recovery System.
G-70-191 (08/08/99)	Healy/Franklin VP-1000 Vapor Pump Phase II Vapor Recovery System (Healy ORVR Phase II Vapor Recovery System).

G-70-196 (12/30/00)	Certification of the Saber Technologies, LLC SaberVac VR Phase II Vapor Recovery System.
------------------------	--

36.9.2 Stage I Vapor Recovery Systems

Number	Description	<u>Date</u>
<u>VR-101-N</u>	<u>Phil-Tite Phase I Vapor Recovery System</u>	<u>June 8, 2013</u>
<u>VR-102-M</u>	<u>OPW Phase I Vapor Recovery System</u>	<u>June 8, 2013</u>
<u>VR-103-G</u>	<u>EBW Phase I Vapor Recovery System</u>	<u>June 3, 2013</u>
<u>VR-104-G</u>	<u>CNI Manufacturing Phase I Vapor Recovery System</u>	<u>June 8, 2013</u>
<u>VR-105-C</u>	<u>EMCO Wheaton Retail Phase I Vapor Recovery</u>	<u>Sept. 14, 2009</u>