

## Delaware Aboveground Storage Tank Requirements For Tanks containing Diesel, Heating Fuel or Kerosene

|   | Registration | New Construction Fee | Annual Fee | Release Reporting & Remediation | Subject to Technical Regulations | Signage |
|---|--------------|----------------------|------------|---------------------------------|----------------------------------|---------|
| ASTs > 250 gallons and ≤ 19,999 gallons*  | X            |                      |            | X                               |                                  |         |
| ASTs > 19,999 gallons and < 40,000 gallons  | X            |                      |            | X                               |                                  | X       |
| ASTs ≥ 40,000 gallons   | X            | \$3,750.00           | \$750.00   | X                               | X                                | X       |
| ASTs > 250 gallons and < 1,100 gallons containing: <ul style="list-style-type: none"> <li>▪ Heating Fuel used on the premises where stored.</li> <li>▪ Motor Fuel or Motor Oil used for non-commercial purposes.</li> <li>▪ Ag/Farm substances including Petroleum products.</li> </ul> |              |                      |            | X                               |                                  |         |
| ASTs installed on a temporary basis, not to exceed six months.  |              |                      |            | X                               |                                  |         |
| ASTs Regulated Pursuant to Title 29 Del. Code §8028. (Boiler Safety Program)  |              |                      |            | X                               |                                  |         |
| ASTs regulated pursuant to Title 7, Del. Code Chapter 77. (Accidental Release Prevention Program)   |              |                      |            | X                               |                                  |         |

ASTs do NOT include: Flow through process tanks, Wastewater treatment works containment vessels, Transformers, Septic Tanks, Pipelines, Propane Tanks

\*ASTs located on a farm have separate requirements.