

Monthly And Yearly Fuel Usage Records

for Stationary Generators Subject to Regulation No. 1144

1. For each month listed, write down the type of fuel used in the generator, and record the amount of fuel used in the generator during that month.
2. Please circle the correct units for the amounts of fuel being recorded:

(GALLONS)
(CUBIC FEET)
(POUNDS)
3. To determine the "Yearly Total", add the previous eleven (11) months' "Fuel Usage" to the current month's "Fuel Usage".
4. For more information about Regulation No. 1144, please contact Air Quality Management at 302-739-9402.

Month	Fuel Type	Fuel Usage	Yearly Total
4/2006	Low Sulfur Diesel Fuel	25	A Yearly Total cannot be determined without 12 months of data. March 2007 will be the first month in which a Yearly Total can be determined.
5/2006	Low Sulfur Diesel Fuel	19	
6/2006	Low Sulfur Diesel Fuel	58	
7/2006	Low Sulfur Diesel Fuel	31	
8/2006	Low Sulfur Diesel Fuel	18	
9/2006	Low Sulfur Diesel Fuel	13	
10/2006	Low Sulfur Diesel Fuel	12	
11/2006	Low Sulfur Diesel Fuel	9	
12/2006	Low Sulfur Diesel Fuel	13	
1/2007	Low Sulfur Diesel Fuel	58	
2/2007	Low Sulfur Diesel Fuel	25	
3/2007	Low Sulfur Diesel Fuel	19	
4/2007	Low Sulfur Diesel Fuel	12	287
5/2007			
6/2007			
7/2007			
8/2007			
9/2007			
10/2007			
11/2007			
12/2007			
1/2008			
2/2008			
3/2008			

Generator Owner's Name and Phone Number: John A. Smith 302-555-5555

Generator Location: 123 Smith Drive City, DE Zipcode

Generator Classification (Emergency or Distributed): Emergency Generator Size (kW): 100 kW

* All records must be kept for a minimum of 5 years, and only need to be submitted to Air Quality when requested.