

## Prettyman Mark A. (DNREC)

---

**From:** Joel Bluestein [jbluestein@eea-inc.com]  
**Sent:** Friday, August 13, 2004 10:56 AM  
**To:** Prettyman Mark A. (DNREC)  
**Cc:** rapweston@aol.com  
**Subject:** Re: 6th DG Workgroup Meeting

Mark - Sorry I won't be able to attend the meeting on Monday. I think the revisions address most of what was discussed at the last meeting. Just a few thoughts by section number:

1.3.1 I think trigger is usually date of operation rather than installation - installation is a little vague.

3.1.2 The ETV is just a testing program. It sets no standards so I'm not sure it really adds much to this section and I'm not sure how difficult it is to have it done or how long it takes. I'd leave that out. Microturbines are so much cleaner than diesel engines that I'd think you'd be happy to have any microturbine as an emergency generator.

4.2 I know that there was some pushback on operating hour limits for O&M but I think you need something there.

Let me know if there's anything else I can help with.

Joel Bluestein  
Energy and Environmental Analysis, Inc.  
Phone 703-528-1900  
Fax 703-528-5106