



Standard Detail & Specifications Riprap Stilling Basin

Construction Notes:

1. The subgrade for the riprap shall be prepared to the required lines and grades as shown on the plan. Any fill required in the subgrade shall be compacted to a density of approximately that of the surrounding undisturbed material.

DELAWARE

IANDBOOK

- 2. The riprap shall conform to the grading limits as shown on the plan.
- 3. Geotextile shall be a Type GS-I. Fabric shall be protected from punching, cutting or tearing. Any damage other than an occasional small hole shall be repaired by placing another piece of cloth over the damaged area. All connecting joints should overlap a minimum of 1 ft. If the damage is extensive, replace the entire section.
- 4. Stone for the riprap or gabion outlets may be placed by equipment. Riprap shall be placed in a manner to prevent damage to the geotextile fabric. Hand placement will be required to the extent necessary to prevent damage to the conduits, structures, etc.

Source:	Symbol:	Detail No.
	\frown	DE-ESC-3.3.11
Adapted from	(RSB)	Sheet 3 of 3
FHWA HEC-14		Effective FEB 2019