



## State of Delaware Public Record Summary Information on Underground Storage Tanks (UST)

**Public Record Posted Date: January 2, 2014**

***General Information:***

**Total Number of UST Facilities subject to federal requirements: 436**

**Total Number of USTs: 1243 subject to federal requirements**

***Summary Information for On-Site Inspections:***

**Number of UST Facilities Inspected (10/1/10 through 9/30/11): 182**

**Percent of facilities found to be in significant operational compliance: 79%**

**Note:** Tank, facility, and on-site inspection information is based on definitions and compliance requirements found in the DE Admin Code 1351, State of Delaware *Regulations Governing Underground Storage Tank Systems*;

**Summary of Release Sources and Causes for the time period 10/1/12 through 9/30/13:**

**Number of Confirmed Releases during the time period 10/1/12 through 9/30/13: 58**

Source			Cause													
			Spill		Overfill		Phys/Mech Damage		Corrosion		Install Problem		Other		Unknown	
	#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%
Tank	8	23	0	0	0	0	0	0	4	50	0	0	0	0	4	50
Piping	2	6	0	0	0	0	1	50	1	50	0	0	0	0	0	0
Dispenser	9	26	0	0	0	0	1	11	0	0	0	0	0	0	8	89
Turbine Pump (STP)	1	2	0	0	0	0	0	0	0	0	0	0	0	0	1	100
Delivery Problem	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Other	15	43	0	0%	0	0%	7	47%	1	7%	0	0%	2	13%	5	33%
<b>Totals</b>	<b>35</b>	<b>100%</b>	<b>0</b>	<b>0%</b>	<b>0</b>	<b>0%</b>	<b>9</b>	<b>26%</b>	<b>6</b>	<b>17%</b>	<b>0</b>	<b>0%</b>	<b>2</b>	<b>6</b>	<b>18</b>	<b>51%</b>

**\* Please note there were 21 additional releases with unknown sources during the reporting period.**

**Note:** Release, source and cause information is based on data collected by State of Delaware employees and are identified through field observation and confirmed with soil testing when retrofit, repair, tank removal, or hydrogeological investigation activities are conducted.

To obtain facility specific information please use our environmental navigator system found at: <http://www.nav.dnrec.delaware.gov/DEN3/> or call Mr. Alex Rittberg at 302-395-2500.

