Department of Natural Resources
and Environmental Control
Tank Management Section
391 Lukens Drive
New Castle, DE 19720
302-395-2500 (phone)
302-395-2555 (fax)
www.dnrec.delaware.gov/Tanks/

## 30-Day Inspection Record for Pressurized Piping Release Detection (RD)

**(Also use for Double Walled Suction Piping RD)**

**YEAR:**

Facility Name:_____

Facility ID#:_____

Release Detection Method: _____

**If piping associated with individual tanks pass on separate days, indicate date, along with "P", in the tanks' column.**

| Month/ Day | Initials | UST System (Piping) (Enter "P" for PASS/ NO RELEASE DETECTED or "F" for a FAIL/ SUSPECTED OR CONFIRMED RELEASE, if "F" Describe Action Taken) | | | | |
|---|---|---|---|---|---|---|
| | | UST # Product: ( P/F ) | UST # Product: ( P/F ) | UST # Product: ( P/F ) | UST# Product: ( P/F ) | If "F"- Action Taken |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |

The Line leak detector and all interstitial monitoring equipment must be tested by a certified technician annually.

**If at any time a release is suspected, call the Tank Management Section within 24 hours or by the next business day, at (302)-395-2500. If you confirm a release has occurred after TMS operating hours, call the DNREC Emergency Hotline, at 1-800-662-8802.**

**This form and any associated release detection documents (ATG printouts, SIR records, equipment test results) must be kept on file for the life of the UST System.**