Department of Natural Resources
and Environmental Control
Tank Management Section
391 Lukens Drive
New Castle, DE 19720
302-395-2500 (phone)
302-395-2555 (fax)
www.dnrec.delaware.gov/Tanks/

30-Day Inspection Record for Impressed Current Cathodic Protection Systems

The Department of Natural Resources and Environmental Control, Tank Management Section (DNREC-TMS) has developed this inspection record to assist tank owners and operators (O/O) in complying with Delaware's *Regulations Governing Underground Storage Tank Systems* (the UST Regulations) Parts B and C, Section 2.25.3., Impressed Current Cathodic Protection Operation and Maintenance Requirements.

Facility Name: _____ **YEAR:**

Facility ID#: _____

Amp Range Recommended: _____

Voltage Range Recommended: _____

Month/Day	Your Name	Voltage Reading	Amp Reading	Record Number of Hours Running	Is Your System Running Properly? (Yes/No)
					☐ Yes ☐ No
					☐ Yes ☐ No
					☐ Yes ☐ No
					☐ Yes ☐ No
					☐ Yes ☐ No
					☐ Yes ☐ No
					☐ Yes ☐ No
					☐ Yes ☐ No
					☐ Yes ☐ No
					☐ Yes ☐ No
					☐ Yes ☐ No
					☐ Yes ☐ No

If the rectifier voltage and/or amperage output(s) are outside the recommended operating levels, contact a cathodic protection professional to address the problem immediately and notify the DNREC-TMS, at 302-395-2500, within forty-eight (48) hours of the discovery of the failure.

NEVER TURN OFF YOUR RECTIFIER. Only certified individuals should adjust the rectifier.

THIS FORM MUST BE KEPT ON FILE FOR THE LIFE OF THE UST SYSTEM.