



## The Quality Chicken People

✓ DAY

### ALLEN HARIM FOODS, LLC

Harbeson Plant  
P.O. Box 63  
18752 Harbeson Rd.  
Harbeson, DE 19951  
TEL (302) 684 - 1640 • FAX (302) 684 - 0584

October 4, 2012

Mr. Glenn Davis, Program Manager  
State of Delaware – DNREC  
Division of Water Resources  
Surface Water Discharges Section  
89 Kings Highway  
Dover, Delaware 19901



Re: Permit #DE0000299  
Outfall 001

Dear Mr. Davis:

This letter is to follow up the October 3, 2012 verbal notification to Beth Krumrine in which the analytical results from the month of September, 2012 at Outfall 001 were reported. Per the notification requirements of Part II, Section A.2.b.1 of the referenced permit Allen Harim Foods, LLC, is reporting the following:

#### Allen's – Harbeson 001 Composite Sample

| Sample Date     | Parameter        | Results                      |
|-----------------|------------------|------------------------------|
| September ,2012 | Total Phosphorus | 18.9 lbs/day Monthly Average |

As shown above Total Phosphorus results for the dates indicated were above the NPDES monthly average limit of 15.0 lbs/day.

Aluminum Chloride feed to the clarifier was investigated on 9-11-12. It was found that a partial plug of the feed line to the clarifier existed. This plug in the aluminum chloride feed line was cleared at approximately 0800 hours on 9-11-12 with dosage rates measured and confirmed to be at our desired set point. That set point was increased to further precipitate Total Phosphorus. The Total Phosphorus results for the composite samples taken on 9-18-12 and 9-25-12 were back in compliance with results to be reported of 0.40 mg/L and 0.13 mg/L respectively.

If you should have any questions, please contact me at (302) 684-1640, Ext. 184.

Respectfully submitted,  
ALLEN HARIM FOODS, LLC.

A handwritten signature in black ink that reads "Michael R. Sausé". The signature is written in a cursive style with a large, prominent "M" and "S".

Michael R. Sausé  
Wastewater Manager

*"Preparing Food for our Families"*