

Allen Family Foods, Inc.

Allen Family Foods, Inc.

Phone:
FAX:
email:

October 3, 2006



Mr. Allen McCloskey
Department of Natural Resources & Environmental Control
Division of Water Resources
89 Kings Highway
Dover, Delaware 19901

Re: Permit #DE 0000299
Discharge 001

This letter is to follow up the 24 hour phone verification with your office that occurred yesterday concerning the composite sample results for the sampling period 9-26-06 through 9-27-06. Per the notification requirements of Part II, Section A.2.(b) of the referenced permit we report the following:

Allen's - Harbeson 001 Composite Sample

Ammonia as N 35.2 lbs/day

The high pounds per day of ammonia as N is currently being investigated. Nitrification bacteria were purchased from Maryland Biochemical, Inc. and will be added to the system today for a period of four days.

If you should have any questions, please do not hesitate to contact me at (302) 684-1640, Ext. 184.

Respectfully submitted,
ALLEN FAMILY FOODS, INC.

A handwritten signature in blue ink that reads "Michael R. Sause".

Michael R. Sause
Environmental Manager

cc: John Evans
Tom Brinson