

# Allen Family Foods, Inc.

Allen Family Foods, Inc.

Phone:  
FAX:  
email:



October 18, 2006

Mr. Allen McCloskey  
Department of Natural Resources & Environmental Control  
Division of Water Resources  
89 Kings Highway  
Dover, Delaware 19901

Re: Permit #DE 0000299  
Discharge 001

This letter is to follow up the 24 hour phone verification with your office that occurred on October 18, 2006 concerning the composite sample results for the sampling period 10-04-06 through 10-08-06. Per the notification requirements of Part II, Section A.2.(b) of the referenced permit we report the following:

### Allen's - Harbeson 001 Composite Samples

Sample Dates	Parameter	Results Reported
10-4-06 to 10-5-06	Ammonia as N mg/L	20.6 mg/L
10-4-06 to 10-5-06	Ammonia as N lbs/day	80.21 lbs/day
10-5-06 to 10-6-06	Ammonia as N mg/L	18.2 mg/L
10-5-06 to 10-6-06	Ammonia as N lbs/day	169.58 lbs/day
10-6-06 to 10-7-06	Ammonia as N mg/L	12.5 mg/L
10-6-06 to 10-7-06	Ammonia as N lbs/day	136.74 lbs/day
10-7-06 to 10-8-06	Ammonia as N mg/L	7.2 mg/L
10-7-06 to 10-8-06	Ammonia as N lbs/day	82.28 lbs/day

The above results of mg/L ammonia as N and lbs/day ammonia as N occurred on the sampling periods noted above and were a result of a plant upset. Additional nitrification bacteria were purchased from Maryland Biochemical, Inc. and were added to the system for a period of four days. The sample results for the period 10-8-06 to 10-9-06 showed the plant to be in compliance with all permit parameters.

If you should have any questions, please do not hesitate to contact me at (302) 684-1640,  
Ext. 184.

Respectfully submitted,  
ALLEN FAMILY FOODS, INC.



Michael R. Sause  
Environmental Manager

cc: John Evans  
Tom Brinson