



STATE OF DELAWARE  
DEPARTMENT OF NATURAL RESOURCES  
& ENVIRONMENTAL CONTROL  
DIVISION OF WATER RESOURCES  
20653 DUPONT BLVD  
UNIT 5  
GEORGETOWN, DE 19947

January 25, 2000

Mrs. Chris DiTullio  
CULTEC, Inc.  
878 Federal Road  
Brookfield CT 06804

RE: Request for 40% reduction allowance on Cultec chambers

Dear Mrs. DiTullio,

The Division of Water Resources is pleased to inform you that we are able to approve the Cultec Contactor 100 for use in accordance with all accepted and approved Departmental policies and procedures regarding the use of gravelless chambers in on-site wastewater treatment and disposal systems in Delaware. This includes the ability to take a 25% reduction in the required drainfield area.

In addition the Cultec Contactor Models 75, 125 and 180 may be used on an individual permit basis in conformance with the State of Delaware Regulations Governing the Design, Installation, and Operation of On-Site Wastewater Treatment and Disposal Systems. When these chambers are used the 25% reduction will still be applicable.

In the case of one of the previously approved gravelless chambers, a 40% reduction was allowed. This reduction is currently under review, by the Department and may at some point be rescinded; however if this does not occur your product will surely be considered for the additional reduction.

Please feel free to contact the Ground Water Discharges Section if you have any questions at 1-302-739-4761

Sincerely,

David W. Reinhold, PE, P.G.  
Program Manager I  
Ground Water Discharges Section

*Delaware's good nature depends on you!*