



STATE OF DELAWARE  
DEPARTMENT OF NATURAL RESOURCES  
& ENVIRONMENTAL CONTROL  
DIVISION OF WATER RESOURCES  
20653 DUPONT BLVD  
UNIT 5  
GEORGETOWN, DE 19947

April 11, 2005

Mr. Dan DeLawyer  
Product Manager  
Fralo Plastech  
One General Motors Drive  
Syracuse, NY 13206

RE: Approval of SEPTECH model 1000E septic tank

Dear Mr. DeLawyer

Based on our review of the technical information you provided on the Fralo Plastech, SEPTECH, ST-1000, 2-compartment septic tank, the Department hereby approves it for use in Delaware.

Please note, however, that all SEPTECH, ST-1000 septic tanks installed in Delaware must conform to Section 6.07000 and Exhibit G of the Regulations Governing the Design, Installation and Operation of On-Site Wastewater Treatment and Disposal Systems. Furthermore, any SEPTECH polyethylene septic tank that will be installed within the seasonal high water table in Delaware must be secured in place using appropriate anchoring or backstays.

Please feel free to contact the Ground Water Discharges Section at (302) 856-4561, if you should have any questions.

Sincerely

A handwritten signature in cursive script that reads "James Cassidy".

James Cassidy  
Program Manager  
Ground Water Discharges Section

*Delaware's good nature depends on you!*