

MEMORANDUM

TO: Class C Designers
Class D Site Evaluators
Class E System Contractors

FROM: John G. Hayes Jr., Ground Water Discharges Section
Hilary Moore, Ground Water Discharges Section
American Manufacturing, Inc.
Geoflow, Inc.

SUBJECT: Micro-Irrigation "Drip" Design Criteria

DATE: November 18, 2003

After additional experience with working on design considerations and siting of micro-irrigation "drip" systems, the Ground Water Discharges Section (GWDS) has amended our previous memo, October 1, 2000. This memo will be the new directive for micro-irrigation "drip" criteria and must be adhered to when siting, designing and constructing micro-irrigation "drip" treatment and disposal systems in Delaware, effective December 1, 2003. The manufacturers (American Manufacturing Inc. and Geoflow, Inc.) presently supplying the "drip" products have agreed to the criteria outlined below.

** Some design considerations and the subsequent approval will be determined on a case by case basis and in those instances when performance based criteria is utilized.

Siting Criteria:

- Micro-irrigation "drip" systems are not the cure all remedy for problem sites, **do not prescribe as such.**
 - Loading rates are to be based on the most restrictive texture within 24" of the surface.
 - For **at-grade systems**, the tillage depths are to be 6-8", although slightly deeper depths may be necessary in the case of shallow thin plow pans or similar restrictive layers within 12" of the surface.

Page 2 – Drip Guidelines

- Landscape position is also a necessary consideration, do not site within a closed depression or where water tends to pond during heavy rainfall events.

New Construction:

Separation requirements;

- 18” from limiting zone
 - * Full Depth installation = 24” limiting zone, 6” trench
 - * Surface installation (At-grade systems) = 18-22” limiting zones require that 3” sandy fill be added, then place tubing 1” into sandy fill and add 6” topsoil cap (*See Design and Construction Notes for Site Preparation*).
 - * *No advanced treatment required* *
- 10 – 17” from limiting zone **requires advanced treatment**. A 12” separation distance must be maintained from the limiting zone. For limiting zones 10-16”, 3” of suitable sandy fill must be added, then place tubing 1” into fill and add 6” topsoil cap.

Replacement System:

Separation requirements:

- 18” from limiting zone – Same installation parameters as above
- 10 – 17” limiting zone – Suitable sandy fill added to establish 20” separation, place tubing 1” into sandy fill and add 6” topsoil cap
 - * *No advanced treatment required unless site evaluator determines otherwise**
- Less than 10” limiting zone **requires advanced treatment** – Suitable sandy fill added to establish 13” separation, place tubing 1” into sandy fill and add 6” topsoil cap.

Design and Construction Notes for At-Grade Systems

- Rope off proposed “drip” disposal area.
- Prepare disposal area when soil moisture is within a satisfactory range.
- Remove vegetation, but do not pull out stumps; do not remove sod, topsoil or rock.
 - Grass, shrubs, and trees must be cut as close to the ground surface as possible and removed, preferably by hand from the site.
 - For wooded lots, with excess litter, we recommend that it be raked from site.

Page 3 – Drip Guidelines

- Chisel plow disposal area 6-8” deep, or as prescribed by site evaluator.
 - Preferred methods
 - Chisel teeth mounted on a backhoe bucket and pulled through surface
 - Chisel plow pulled behind a tractor

******* ROTOTILLERS SHALL NOT BE UTILIZED*******

- Add 3” of sandy fill, and place tubing 1” into sandy fill.
- Add 6” top soil cap over area.
- To maintain positive drainage additional cover on top may be necessary.

If in doubt, please call the GWDS at 739-4762, prior to beginning any construction procedures.

Delaware Residential “Drip” Design Criteria

Soil Type	Permeability Rate (mpi)	Hydraulic Loading Rate (gpd/ft ²)	Drip – Line Spacing	Emitter Spacing
S	5	.303	Typically 24”	Typically 24”
LS	10	.278		
	15	.253		
SL	20	.228		
	25	.211		
SCL, L	30	.203		
	35	.196		
	40	.189		
	45	.180		
Si, SiL	50	.173		
	55	.162		
	60	.154		
	65	.146		
	70	.139		
CL, SiCL	75	.133		
	80	.127		
	85	.122		
	90	.117		
	95	.116		
	100	.105		
	105	.096		
	110	.088		
	115	.080		
SC, SiC, C	120	.073		

Notes:

1. Primary effluent systems require automation of filter and field flushing.
2. Spacing of drip-line and emitters may also be a function of soil textures and landscaping requirements. Please contact manufacturer for recommendations and limitations.
3. For commercial and/or large systems, please contact the GWDS and the manufacturers for additional siting criteria.