



STATE OF DELAWARE  
DEPARTMENT OF NATURAL RESOURCES  
& ENVIRONMENTAL CONTROL  
DIVISION OF WATER RESOURCES  
20653 DUPONT BLVD  
UNIT 5  
GEORGETOWN, DE 19947

January 26, 2000

Mr. R.C. DiCicco  
Stelling Company Inc.  
723 Hiawatha Blvd. West  
Syracuse, NY 13204

RE: Approval of the Enviro Plus polyethylene septic tanks

Dear Mr. DiCicco

The Division of Water Resources is pleased to inform you that we are able to approve the Enviro Plus polyethylene septic tank for use in On-Site Wastewater Treatment and Disposal Systems in the State of Delaware.

The following models are approved as direct equals to their masonry counterparts. The X143850 for the 1000 gallon septic tank, the X144700 for the 1250 gallon septic tank, and the X145500 for the 1500 gallon septic tank. In the event that the design, construction, or materials used in the manufacturing of the tanks should change, re-approval by the Department will be required. On occasion the Division does require that larger septic tanks be used; the Department must approve any septic tanks other than these noted, prior to use.

Please feel free to contact the Ground Water Discharges Section if you have any questions at 1-302-739-4761.

Sincerely,

David W. Reinhold, PE, P.G.  
Program Manager I  
Ground Water Discharges Section

*Delaware's good nature depends on you!*