

Final Design Summary of Wastewater Treatment System Upgrade & Expansion (Phase 1)



**Allen Harim Foods, LLC.
Harbeson, Delaware**

August 21, 2015



Prepared by:



Reid Engineering Company, Inc.
Environmental & Civil Engineering Consultants
540-371-8500 | www.ReidEngineering.com
1210 Princess Anne Street | Fredericksburg, VA 22401
Contact: John H. Reid, P.E. Email: jreid@reidengineering.com

QUALITY

VALUE

COMMITMENT

**FINAL DESIGN SUMMARY OF WASTEWATER
TREATMENT SYSTEM UPGRADE & EXPANSION**

**Phase 1
for
ALLEN HARIM, LLC.
Harbeson, Delaware**

TABLE OF CONTENTS

| | |
|--|----|
| A. GENERAL DESIGN REQUIREMENTS | 1 |
| B. RAW WASTEWATER INFLUENT PUMP STATION (Modification)..... | 4 |
| C. FLOW EQUALIZATION BASIN (New)..... | 5 |
| D. FEB EFFLUENT/DAF CELL INFLUENT PUMP STATION (New)..... | 10 |
| E. DISSOLVED AIR FLOTATION DAF CELL PRETREATMENT SYSTEM (Existing) ... | 12 |
| F. CHEMICAL FEED EQUIPMENT FOR DAF PRETREATMENT SYSTEM..... | 17 |
| G. DAF CELL EFFLUENT PUMP STATION (Modification)..... | 17 |
| H. 7 DAY FLOW EQUALIZATION BASIN ANOXIC REACTOR #1A & #1B (Existing)... | 19 |
| I. FEB ANOXIC REACTOR EFFLUENT PUMP STATION (Modification) | 27 |
| J. NITRIFICATION REACTOR #2A & #2B (Existing & New)..... | 29 |
| K. CLARIFIER INFLUENT FLOW SPLITTER & FLOCCULATION TANK FOR CLARIFIERS #1 (Existing) & #2 (New) | 37 |
| L. FINAL CLARIFIER (Existing & New) | 39 |
| M. RETURN ACTIVATED SLUDGE (RAS) PUMP STATION (Modification)..... | 40 |
| N. WASTE ACTIVATED SLUDGE (WAS) PUMP (New) | 42 |
| O. ULTRAVIOLET (UV) FINAL EFFLUENT DISINFECTION SYSTEM (New)..... | 43 |
| P. CHLORINE CONTACT BASIN (Existing) | 44 |
| Q. WASTE ACTIVATED SLUDGE PRODUCTION | 45 |
| R. WASTE ACTIVATED SLUDGE STORAGE TANKS (Existing & New) | 48 |
| S. CLARIFIER SCUM PUMP STATION (Existing) | 50 |
| T. EFFLUENT FLOW METER (Existing) | 51 |
| U. CHEMICAL STORAGE-FEED EQUIPMENT FOR ACTIVATED SLUDGE PROCESS (Existing) | 51 |
| V. CHEMICAL STORAGE-FEED EQUIPMENT FOR PHOSPHORUS REMOVAL (Existing) | 53 |

| | |
|---|----|
| W. CHEMICAL STORAGE-FEED EQUIPMENT FOR FINAL EFFLUENT PH CONTROL (Existing) | 54 |
| X. EXPECTED FINAL EFFLUENT QUALITY AND FINAL EFFLUENT NPDES PERMIT LIMITATIONS | 55 |

**FINAL DESIGN SUMMARY OF
WASTEWATER TREATMENT SYSTEM UPGRADE & EXPANSION
Phase 1
for
Allen Harim, LLC.
Harbeson, Delaware**

A. GENERAL DESIGN REQUIREMENTS

1. Description of Project

- a. Allen Harim is expanding their chicken processing plant in Harbeson, Delaware from the existing production capacity of 175,000 birds/day and 875,000 birds/week over 5 processing days/week up to 393,000 birds/day and 1,965,000 birds/week over 5 processing days/week. The design capacity of the existing on-site wastewater treatment system is approximately 1,250,000 gallons/day of wastewater which is highly treated prior to disposal by direct discharge. The expanded processing plant is expected to generate a maximum volume of 2,000,000 gallon/day of wastewater, 5 days/week. Consequently, the existing wastewater treatment system must be expanded to increase the treatment capacity provided by the wastewater treatment system in order to accommodate this processing plant expansion.
- b. In order to expand the processing plant and discharge the increased volume of treated wastewater, the Allen Harim NPDES permit must be modified for the higher maximum daily design flow capacity of 2,000,000 gpd. At this higher wastewater discharge volume, the NPDES permit limits for BOD, TSS, fecal coliform and especially Total Nitrogen and Total Phosphorus will be reduced vs. the existing permit limits. Consequently, the existing wastewater treatment process must be upgraded to increase the pollutant removal efficiency attained by the wastewater treatment system in order to comply with the new more restrictive discharge permit limits.
- c. The existing wastewater treatment system will be upgraded in two phases. The first phase will address the increased wastewater flow volume and will consist of the following upgrades:
 - New Raw Wastewater Pump Station Pumps
 - New Flow Equalization Basin
 - Modify Existing DAF Pretreatment System
 - Modify Existing DAF Cell Effluent Pump Station Pumps
 - New FEB Anoxic Effluent Pump Station

- New Clarifier No. 2
- Modify RAS Pump Station
- New WAS Pump
- New Ultraviolet Disinfection System

Phase two will address the upgrade to the BNR system to meet the anticipated permit limits of the new NPDES permit. Phase two will consist of the following upgrades:

- New Nitrification Reactor #2B
- New Anoxic Reactor #3
- New Aerobic Reactor #4
- New Flow Splitter
- New Tertiary Filtration System
- New Equipment Building
- Conversion of Existing Nitrification Reactor #2B into Waste Sludge Storage Tank #3
- New Sludge Screw Press
- Various Process Piping Modifications

2. Wastewater Sources

a. Processing Facility

- 1) Wastewaters discharged from the processing will be treated through a physical chemical pretreatment system; a biological final treatment system; and ultraviolet disinfection system to reduce high concentrations of BOD, Suspended Solids, Oil & Grease, TKN; Ammonia Nitrogen, Total Nitrogen, Total Phosphorus, Fecal Coliform and Enterococcus Bacteria pollutants to comply with NPDES permit limitations before being discharged into Beaver Dam Creek.

b. Sanitary Wastewater

- 1) Sanitary wastewater generated from the bathroom facilities at the processing plant and wastewater plant will be segregated and treated through an on-site sanitary wastewater treatment system package plant with effluent disinfected and discharged to mix with the treated process wastewater prior to discharge through the 001 outfall.

3. Production Capacity, Wastewater Flow Volumes and Pollutant Concentrations and Loadings

a. Processing Facility Production Capacity

- 1) The existing processing plant production capacity is 175,000 chickens/day @ 6.0#LWK/bird over one kill shift and one clean up shift per day, 5 days/week = 875,000 chickens/week @ 6.0 to 7.0 gallons wastewater/bird.
- 2) The expansion processing plant production capacity is 393,000 chickens/day @ 6.5#LWK/bird over two kill shifts and one clean-up shift per day, 5 days/week = 1,965,000 chickens/week @ 5 gallons wastewater/bird.

b. Wastewater Flows

- 1) Maximum daily wastewater flow volume for 393,000 birds/day slaughter capacity @ 5 gallons/bird of wastewater = 2,000,000 gallons/day including sanitary fixtures for employees.
- 2) The wastewater volume generated by the processing plant during the two 8 hour processing shifts = 1.60 MG and during the one 7 hour clean-up shift = 0.40 MG. Wastewater will be generated by the processing plant at a flow rate of approximately 1,667 gpm = 2.40 MGD during the two 8 hour processing shifts and approximately 950 gpm = 1.40 MGD during the one 8 hour clean-up shift.
- 3) Maximum flow rate during processing shifts \leq 2,100 gpm
- 4) Average flow rate during processing shifts = 1,667 gpm
- 5) Average flow rate during clean-up shift = 950 gpm
- 6) Feathers and meat offal removed by screening in the processing plant offal room will be disposed to an off-site rendering plant.

c. Wastewater Pollutant Concentrations and Loadings

- 1) Screened, raw wastewater pollutant concentrations and loadings at the maximum daily wastewater flow volume of 2.00 MGD:

Table #1
Screened Raw Wastewater Pollutant Concentrations and Loadings

| Pollutant | Pollutant Concentration | | Pollutant Loading | |
|---------------|-------------------------|------------|-------------------|-------------|
| | Average | Maximum | Average | Maximum |
| BOD (total) | 1,950 mg/L | 2,250 mg/L | 32,526#/day | 37,530#/day |
| BOD (soluble) | 650 mg/L | 850 mg/L | 10,842#/day | 14,178#/day |
| TSS | 1,000 mg/L | 1,500 mg/L | 16,680#/day | 25,020#/day |
| O&G | 400 mg/L | 600 mg/L | 6,672#/day | 10,008#/day |
| TKN | 135 mg/L | 175 mg/L | 2,252#/day | 2,919#/day |
| Ammonia-N | 20 mg/L | 30 mg/L | 334#/day | 500#/day |
| TP | 19 mg/L | 22 mg/L | 317#/day | 367#/day |

B. RAW WASTEWATER INFLUENT PUMP STATION (Modification)

1. General Description

- a. The Raw Wastewater Pump Station is provided to pump screened raw wastewater into the new DAF Pretreatment System Flow Equalization Basin.
- b. The existing Raw Wastewater Pump Station will be modified to expand pump station capacity by installation of two new 10” self-priming pumps to replace the two existing 8” pumps in order to increase pumping capacity out of the existing wet well.
- c. The two new pumps will have larger motors than the existing pumps in order to increase the head and capacity of the pumps.

2. Design Assumptions

a. Wastewater Flow Rates

- 1) Peak flow rate $\leq 2,800$ gpm = 4.0 MGD

- 2) Maximum flow rate $\leq 2,100$ gpm = 3.00 MGD during processing shifts
- 3) Average flow rate = 1,667 gpm = 2.40 MGD during processing shifts

b. Wastewater Pumping Requirements

- 1) Operation of one pump at reduced speed is required to pump the design average flow rate = 1,667 gpm during processing shifts
- 2) Operation of one pump at reduced speed is required to pump the design maximum flow rate = 2,100 gpm during processing shifts
- 3) Operation of one pump at full speed is required to pump the design peak flow rate = 2,800 gpm
- 4) The second pump is provided as an installed standby.

c. Pump Selection

- 1) Two new 40 HP, 10" self-priming wastewater pumps are provided to replace the two existing pumps.
- 2) Each pump is rated at 2,800 gpm @ 45 ft. head when operated at full speed.

d. Variable Speed Drives

- 1) Each pump is provided with a 40 HP variable speed drive motor controls with automatic pump speed and pumping rate control.
- 2) Pump speed and pumping rate will be automatically controlled by the liquid level in the pump station wet well.
- 3) Automatic Lead, Lag and Standby pump operation and sequencing is provided with high liquid level alarm and automatic pump on/off liquid levels.

C. FLOW EQUALIZATION BASIN (New)

1. General Description

- a. One new Flow Equalization Basin (FEB) will be installed and operated to collect screened raw wastewater discharged from the processing plant offal room and provide hydraulic flow equalization upstream of the existing DAF Cell wastewater pretreatment system.

- b. One new above grade FEB tank will be provided with a maximum storage volume of approximately 600,000 gallons.

2. Wastewater Volumes and Flow Rates

- a. Average daily wastewater flow volume = ADF = 1,600,000 gpd, 5 days/week
- b. Maximum daily wastewater flow volume = MDF = 2,000,000 gpd, 5 days/week
- c. Average daily flow pumping rate out of the FEB = 1.60 MGD = 1,100 gpm, 24 hours/day
- d. Maximum daily flow pumping rate out of the FEB = 2.00 MGD \leq 1,400 gpm, 24 hours/day

3. Pollutant Concentrations and Loadings

- a. Maximum and average wastewater pollutant concentrations and loadings in the screened raw wastewater at MDF = 2.00 MGD:

Table #1
Screened Raw Wastewater Pollutant Concentrations and Loadings

| Pollutant | Pollutant Concentration | | Pollutant Loading | |
|---------------|-------------------------|------------|-------------------|-------------|
| | Average | Maximum | Average | Maximum |
| BOD (total) | 1,950 mg/L | 2,250 mg/L | 32,526#/day | 37,530#/day |
| BOD (soluble) | 650 mg/L | 850 mg/L | 10,842#/day | 14,178#/day |
| TSS | 1,000 mg/L | 1,500 mg/L | 16,680#/day | 25,020#/day |
| O&G | 400 mg/L | 600 mg/L | 6,672#/day | 10,008#/day |
| TKN | 135 mg/L | 175 mg/L | 2,252#/day | 2,919#/day |
| Ammonia-N | 20 mg/L | 30 mg/L | 334#/day | 500#/day |
| TP | 19 mg/L | 22 mg/L | 317#/day | 367#/day |

4. FEB Design

- a. Required volume for 24 hour flow equalization is calculated as follows:
 - 1) Maximum daily wastewater effluent pumping volume and flow rate = 2.00 MGD = 1,400 gpm.

- 2) The Maximum influent flow volume over two processing shifts = 2,000,000 gallons (0.80) = 1,600,000 gallons.
 - a) Assume the 1,600,000 gallon flow volume is discharged into FEB's over 15 hours during two processing shifts $\leq 1,800$ gpm
 - b) Required equalization volume over processing shift = $(1,800 - 1,400)(15 \text{ hr})(60) = 360,000$ gallons $\leq 400,000$ gallons
- 3) The Maximum influent flow volume over clean-up shift = 2,000,000 gallons (0.20) = 400,000 gallons.
 - a) Assume 400,000 gallons is discharged into the FEB during the first 6 hours of the clean-up shift. The influent flow rate over the first 6 hours = 1,100 gpm.
 - b) Required Equalization Volume over clean-up shift = $(1,100 - 1,400)(6)(60) = 0$ gallons

4) Total Required Equalization Volume:

| | |
|------------------------------------|------------------------|
| Processing Shift | = 400,000 |
| Clean-up Shift | = <u>0</u> |
| | |
| Total Equalization Volume Required | $\leq 400,000$ gallons |

b. Tank Sizes and Flow Equalization Capacity

- 1) The new FEB Tank is 64.5 ft. dia. x 24.5 ft. maximum liquid depth x 26 ft. tall with a maximum volume of approximately 600,000 gallons.
- 2) The minimum operating water level in the FEB is 8.25 feet which provides a residual operating volume of approximately 200,000 gallons.
- 3) The available equalization volume in the FEB is calculated as follows:

600,000 gallons – 200,000 gallons = 400,000 gallons
- 4) The new FEB tank will provide sufficient surge storage volume to equalize and reduce the average wastewater flow rate that must be pumped into the downstream DAF cell down to approximately 1,100 to 1,400 gpm.

c. FEB Normal Operation and Alternative Operation

- 1) Screened raw wastewater is discharged from the offal room by gravity flow into the existing Raw Wastewater Pump Station from where it is pumped into the new FEB tank.
- 2) Two FEB Tank Effluent/DAF Cell Influent Pumps are provided with VFDs, discharge flow meter and automatic pumping rate control to pump equalized and aerated screened raw wastewater at a relatively constant set point flow rate ranging from 1,100 gpm to 1,400 gpm from the FEB Tank into the DAF Cell.
- 3) If the new FEB Tank must be taken out of service, wastewater can be pumped from the Raw Wastewater Pump Station directly into the DAF Cell and by-pass the FEB tank.

d. Evaluate Mixing and Aeration requirements in the New FEB:

- 1) bhp required for mixing 1,000 mg/L to 1,500 mg/L TSS concentration = 40 HP/MG

$$\text{bhp required} = 40 \text{ HP}(0.60) \leq 25 \text{ HP}$$

$$\text{cfm required for mixing} \leq 15 \text{ scfm}/1000\text{ft}^3 \text{ with FEB @ } 80 \times 10^3\text{ft}^3$$

$$\text{cfm required} = 15 \text{ scfm}(80) = 1,200 \text{ scfm}$$

- 2) At the average pollutant loading, assume an oxygen uptake rate in the FEB Tank of $0.15\#O_2/\#BOD$. The oxygen demand to maintain aerobic conditions in the FEB Tank is calculated as follows:

$$\text{AOTR} = \frac{0.15\#O_2/\#BOD (32,526\#BOD/\text{day})}{24}$$

$$\leq 200\#O_2/\text{hr}$$

- 3) At the maximum pollutant loading, assume an oxygen uptake rate in the FEB Tanks of $0.15\#O_2/\text{hr}/\#BOD$. The oxygen demand to maintain aerobic conditions in the FEB Tank is calculated as follows:

$$\text{AOTR} = \frac{0.15\#O_2/\#BOD (37,530\#BOD/\text{day})}{24}$$

$$\leq 233\#O_2/\text{hr}$$

- e. Calculate the required corresponding maximum standard oxygen transfer rate required:

$$SOTR = AOTR \left[\frac{C_{ss}}{(\beta C_{sw} - DO) \alpha (1.024)^{T-20}} \right]$$

Where DO = 1.0 mg/L (average DO in FEB Tank)

β = 0.90

α = 0.75 @ 1,000 to 2,000 mg/L TSS concentration with subsurface coarse bubble aeration diffusers

$1.024^{(T-20)}$ = 1.209 @ maximum T = 28° C

C_w = 7.92 mg/L @ sea level, 28° C

C_s = 9.20 mg/L @ sea level, 20° C

Site Altitude ≤ 500 feet

Pressure Correction Factor ≥ 0.98

$$C_{sw} = 7.92 \left[\frac{(0.982)(14.7) + (0.5)(0.433)(24.0)^*}{14.7} \right]$$

$$= 7.92 \text{ mg/L}(1.336) = 10.57 \text{ mg/L}$$

$$C_{ss} = 9.20 \left[\frac{14.7 + (0.5)(0.433)(24.0)^*}{14.7} \right]$$

$$C_{ss} = 9.20 \text{ mg/L}(1.354) = 12.45 \text{ mg/L}$$

* 24 foot maximum liquid depth in FEB with the coarse bubble diffusers installed 1.0 above the basin floor.

$$SOTR = \frac{12.45}{AOTR[(0.90)(10.57)-2.0]0.75(1.209)}$$

$$SOTR \leq 1.71 \text{ (AOTR)}$$

$$SOTR \leq 1.75(233) = 400\#O_2/\text{hr}$$

f. Calculate subsurface aeration equipment air sparging requirements:

1) The oxygen available per cfm per hour =

$$\begin{aligned}x &= 0.23 (0.075\#/ft^3)(60 \text{ min/hr}) \\ &= 1.035\#O_2/\text{cfm/hr @ } 68^\circ \text{ inlet air}\end{aligned}$$

2) e = subsurface diffuser oxygen stripping or transfer efficiency at 16.5 ft. average liquid depth = 13%

3) scfm required = $\frac{SOTR}{(x)(e)}$

$$\text{scfm}_1 = \frac{400\#O_2/\text{hr}}{(1.035)(0.13)}$$

$$\leq 3,000 \text{ scfm}$$

4) Max. design blower pressure with 23.5 ft. max. diffuser air sparge submergence plus 0.50 ft. surge depth in FEB:

$$= (24.0 \text{ ft.})(0.433) + 1.0 \text{ psi} = 11.4 \text{ psi} \leq 11.5 \text{ psi (pressure loss plus pressure drop in air supply lines and air diffuser sparges)}$$

g. Oxygen transfer and mixing in the new FEB will be provided by a coarse bubble diffuser system with the diffusers installed approximately 1.0 ft. above the basin floor. The design average air sparging rate in the FEB is 1,500 scfm providing an oxygen transfer rate of approximately 200#O₂/hr (AOTR) with one blower in operation @ maximum liquid depth = 24.0 ft. The design maximum air sparging rate in the FEB is 3,000 scfm providing an oxygen transfer rate of approximately 100#O₂/hr (AOTR) with two blowers in operation @ average liquid depth = 16.0 ft. Compressed air is supplied by 2 - 150 HP positive displacement blowers each rated at 1,500 scfm at 12.0 psi. Each blower shall be provided with a manual variable speed drive. Normally one blower will be operated at reduced speed to supply the required minimum air flow for mixing in the FEB, and, one or two blowers operated at reduced speed to supply the required air flow to FEB to meet the oxygen transfer requirements.

D. FEB EFFLUENT/DAF CELL INFLUENT PUMP STATION (New)

1. Wastewater Flow Volume and Rates

a. Average daily wastewater flow effluent pumping volume and rate = 1.60 MGD = 1,100 gpm

- b. Maximum daily wastewater flow effluent pumping rate = 1,400 gpm = 2.00 MGD

2. Pump Selection

- a. Screened equalized and aerated raw wastewater will normally be pumped from the FEB Tank to the existing DAF Cell wastewater pretreatment system.
- b. Two (2) new 40 HP, 8" self-priming suction lift pumps are provided to pump screened raw wastewater from the FEB tank through a new 10" force main into the existing DAF cell influent pipeline flocculator operated upstream of the DAF Cell wastewater pretreatment system.
- c. Each pump is rated at 1,400 gpm @ 43 feet. Operation of one pump at full speed is required to pump the design maximum flow rate of 1,400 gpm with the second pump provided as an installed standby pump.

3. Variable Speed Drive Controls

- a. Each pump is provided with a 40 HP variable speed drive motor with automatic pump speed and pumping rate control.
- b. The pumps will be normally operated to maintain a constant flow rate pumped from the FEB tank to the DAF Cell. The pumps are provided with variable speed drive motor controls which use the downstream flow meter flow measurement signal and the VFD control panel to automatically control pump operating speed to maintain a manually selected flow rate into the DAF Cell. As the liquid level in FEB Tank rises or falls and the pump head is reduced or increased, the pump speed will be automatically reduced or increased to maintain the desired flow rate into the DAF Cell.

4. Liquid Level Controls

- a. The FEB pumps are manually started. Low liquid level (LLL) automatic pump shut off and alarm level controls are provided in the FEB Tank. Pumps can also be manually operated to pump below the automatic off liquid level in order to drain the FEB.
- b. A high liquid level alarm (HLLA) is provided in the FEB in order to prevent excessive liquid level in the FEB tank.
- c. A high liquid level emergency overflow pipe is also provided in the FEB Tank to discharge overflow into the DAF Cell Effluent Pump Station Wet Well.

5. Flow Meter and Flow Controls

- a. One new 10" dia. magnetic flow meter is provided in the DAF influent line into the Flocculation Tube of the existing DAF Cell.
- b. The flow meter is used with the DAF Cell Influent Pump Station Control Panel for automatic control of pump speed and pumping rate from the FEB Tank into the DAF Cell and flow pacing of chemical feed pumps used to dose chemical solutions for coagulation and flocculation of wastewater upstream of the DAF cell.
- c. The flow meter has a flow indicator and totalizer and is provided with a downstream valve to optionally manually regulate the flow rate pumped out of the FEB tank into the downstream DAF Cell.

E. DISSOLVED AIR FLOTATION DAF CELL PRETREATMENT SYSTEM (Existing)

1. General

- a. Wastewater will be pumped from the new FEB Tank at a relatively constant flow rate 24 hours/day on processing days into the existing DAF Cell for pretreatment of BOD, TSS, Oil and Grease, TKN and TP prior to discharge into the activated sludge final treatment system.
- b. The existing DAF Cell has an existing Flocculation Tube.
- c. The existing DAF cell will be upgraded by the installation of two new recycle pressurization pumps, recycle flow piping and air control panel in order to improve efficiency and capacity.

2. Design Assumptions

- a. Wastewater Flow Rates and Volumes:
 - 1) Average Influent Flow Rate = 1.60 MGD = 1,100 gpm, over 24 hours/day, 5 days/week
 - 2) Maximum Influent Flow Rate = 2.00 MGD = 1,400 gpm, over 24 hours/day, 5 days/week

- b. Maximum and average wastewater pollutant concentrations and loadings in the screened raw wastewater at MDF = 2.00 MGD:

Table #1
Screened Raw Wastewater Pollutant Concentrations and Loadings

| Pollutant | Pollutant Concentration | | Pollutant Loading | |
|---------------|-------------------------|------------|-------------------|-------------|
| | Average | Maximum | Average | Maximum |
| BOD (total) | 1,950 mg/L | 2,250 mg/L | 32,526#/day | 37,530#/day |
| BOD (soluble) | 650 mg/L | 850 mg/L | 10,842#/day | 14,178#/day |
| TSS | 1,000 mg/L | 1,500 mg/L | 16,680#/day | 25,020#/day |
| O&G | 400 mg/L | 600 mg/L | 6,672#/day | 10,008#/day |
| TKN | 135 mg/L | 175 mg/L | 2,252#/day | 2,919#/day |
| Ammonia-N | 20 mg/L | 30 mg/L | 334#/day | 500#/day |
| TP | 19 mg/L | 22 mg/L | 317#/day | 367#/day |

3. DAF System Design

a. General Description

- 1) One existing 10 ft. wide x 44 ft. long x 10 ft. liquid depth rectangular DAF Cell is provided with two new recycle flow pressurization pumps, a new air dissolving system and one existing pipeline flocculator to provide wastewater pretreatment by chemical coagulation and flocculation and dissolved air flotation. One 12" diameter x 80 ft. long, 500 gallon volume Flocculation Tube is provided with the DAF Cell. The effective flotation area of the DAF Cell > 400 ft².
- 2) The new 30 HP recycle pressurization pumps each rated at 302 gpm at 205 ft. head are provided with compressed air fed into the pump discharge piping.
- 3) One new Air Compressor is provided for air supply to the DAF cell air dissolving system and recycle pressurization pump discharge.

b. Design Calculations

- 1) Calculate the maximum DAF Cell solids loading rate with upstream chemical coagulation-flocculation @ 1,400 gpm = 2.00 MGD assuming a BOD removal efficiency of 70%, a TSS removal efficiency of 90% and a O&G removal efficiency of 85%.

a)
$$\frac{[1,500 \text{ mg/L TSS}](0.90) 8.34 (2.00 \text{ MGD})}{24} \leq 1,000\#/hr$$

2) Calculate the required air dissolving rate for the maximum solids loading rate of 1,000#/hr, assuming an air to solids ratio = 0.01#air/#solids in the rectangular DAF cell with polymer coagulation/flocculation.

a)
$$\frac{1,000 (0.01)}{60} < 0.17\# \text{ air/min.}$$

3) Calculate the required air supply rate @ 90°F inlet air density @ ≤ sea level altitude ≥ .071#/ft³

a)
$$\frac{0.17\#/min}{0.071} \leq 2.50 \text{ cfm}$$

b) Use air supply rate = 1.0 cfm to 3.0 cfm = 30 to 90 liters/min.

4) The maximum air dissolving capacity of the DAF Cell recycle pressurization system with one 30 HP recycle pressure pump in operation = 100 liters air/min. ≥ 3.5 cfm.

5) Calculate the pressurized flow required @ 90 psi air dissolving pressure @ wastewater temperature = 90°F max., assuming an air dissolving capacity = 0.864# air/min. @ 90 psi

a)
$$QR = \frac{0.17\#/min (1000)}{0.864\# \text{ air/min}} \leq 200 \text{ gpm}$$

One 30 HP recycle pressure pump is provided with the DAF Cell rated @ 302 gpm @ 205 psi. A second uninstalled pump is provided as a standby.

6) Calculate the maximum DAF Cell Hydraulic Surface Loading Rate

a) Hydraulic Surface Loading Rate =

$$\frac{1,400 \text{ gpm}}{400 \text{ ft}^2} \leq 3.5 \text{ gpm/ft}^2$$

7) Calculate the maximum DAF Solids Loading Rate =

a) Solids Loading Rate =

$$\frac{1,000\#/hr}{400\text{ ft}^2} \leq 2.5\#/ft^2/hr$$

4. DAF Sludge Production Storage and Pumping

- a. The calculated total skimmings volume produced per day in the DAF Cell when operated with chemical coagulation-flocculation = 18,000# to 24,000# dry solids/day = 12,000 to 22,000 gpd after gravity decanting for approximately 20% solids concentration, assuming approximately 70% BOD removal, 90% TSS removal and 85% Oil & Grease removal, TKN removal of 30% to 50% and TP removal of 30% to 50% in the DAF Cell.
- b. Solids skimmed from DAF Cell will flow into a 2,500 gallon Sludge Holding Compartment at the end of the Flotation Cell from where solids will be pumped to an existing 20,000 gallon portable storage tank or to a tanker truck parked adjacent to the equipment building for further storage prior to hauling to final disposal.
- c. Three new 7.5 HP DAF positive displacement sludge pumps are provided each rated at 100 gpm @ 60 ft. to transfer DAF sludge from the Flotation Cell Sludge holding Compartment to the DAF Sludge Storage Tanker for hauling to an off-site disposal site.

5. Expected DAF Pretreatment System Effluent Quality

- a. The following DAF Pretreatment System effluent quality, as summarized in Table #2, is expected if the DAF Cell is operating with a high efficiency chemical program using aluminum chloride coagulant solution and anionic polymer flocculant solution for chemical coagulation and flocculation in the Flocculation Tube upstream of the DAF Cell. The following pretreatment system effluent quality is expected to be discharged into the downstream activated sludge final treatment system at the 2.00 MGD maximum daily discharge flow volume:

Table #2
DAF Pretreatment System Effluent Pollutant Concentrations Required for Acceptable Performance of Downstream BNR Final Treatment System

| Pollutant | Average Concentration | Maximum Concentration |
|------------------|------------------------------|------------------------------|
| BOD | BOD = 1,950(0.30) ≤ 600 mg/L | BOD = 2,250(0.35) ≤ 800 mg/L |
| TSS | TSS = 1,000(0.10) ≤ 100 mg/L | TSS = 1,500(0.10) ≤ 150 mg/L |
| O&G | O&G = 400(0.15) ≤ 60 mg/L | O&G = 600(0.15) ≤ 100 mg/L |
| TKN | TKN = 135(0.50) ≤ 75 mg/L | TKN = 175(0.70) ≤ 125 mg/L |
| TP | TP = 19 (0.50) ≤ 10 mg/L | TP = 22(0.70) ≤ 20 mg/L |

Table #3
Pollutant Loadings in DAF Pretreatment System
Effluent at 2,000,000 gpd Wastewater Flow Volume

| Pollutant | Average Loading | Maximum Loading |
|------------------|------------------------|------------------------|
| BOD | 10,000#/day | 13,344#/day |
| TSS | 1,668#/day | 2,502#/day |
| O&G | 1,000#/day | 1,668#/day |
| TKN | 1,251#/day | 2,085#/day |
| TP | 167#/day | 334#/day |

F. CHEMICAL FEED EQUIPMENT FOR DAF PRETREATMENT SYSTEM

1. Bulk Coagulant Solution Storage Tank

- a. One existing 10' dia. x 12' tall, 6,000 gallon volume, fiberglass double walled tank is provided for bulk storage of aluminum chloride coagulant solution. The bulk tank is located in the existing wastewater shop.
- b. The existing bulk coagulant solution storage tank is provided with containment and has a ultrasonic level control with high and low level alarm with continuous level indicator.

2. Polymer Solution Mix Tanks

- a. Two existing 6'-6" dia. x 10' tall, 2,400 gallon volume fiberglass tanks each with 2 HP mixer are provided for make-up and storage of wastewater shop anionic polymer flocculant solution. The tanks are located in the existing building.

3. Chemical Solution Pumps

- a. Two coagulant solution pumps are provided each rated at 25 gphr @ 30 psi for dosage of coagulant solution into the wastewater flow into the DAF Cell Flocculation Tube. The coagulant solution pumps are located in the existing wastewater shop building.
- b. Two polymer solution pumps are provided each rated at 90 to 900 gphr @ 40 psi for dosage of anionic flocculant solution into the wastewater flow into the DAF Cell Flocculation Tube. The polymer solution pumps are located in the existing wastewater shop building.
- c. The coagulant solution and polymer solution chemical feed pumps have variable speed drives that can be manually controlled; or, automatically controlled by flow pacing from the DAF cell influent flow meter and the chemical feed control system.

G. DAF CELL EFFLUENT PUMP STATION (Modification)

1. General Description

- a. The DAF Cell Effluent Pump Station is provided to pump pretreated wastewater discharged from the DAF cell into the downstream activated sludge biological treatment process Flow Equalization Basin (FEB) Reactor #1A.

- b. The existing DAF Cell Effluent Pump Station will be modified by installation of three new increased HP motors for the existing 8" self-priming pumps in order to increase pumping capacity out of the existing wet well.
- c. The new pumps will have larger motors to increase the head and capacity of the pumps in the pump station.

2. Design Assumptions

- a. Average pumping rate = 1.60 MGD = 1,100 gpm
- b. Maximum pumping rate = 2.00 MGD = 1,400 gpm
- c. Peak pumping rate = 2,800 gpm

3. Pump Selection

- a. Three new 50 HP motors will be provided to upgrade the three existing 8" self-priming sewage pumps to pump pretreated wastewater discharged from the existing DAF cell effluent wet well into FEB Reactor #1A or Nitrification Reactor #2A of the activated sludge final treatment system.
- b. Each pump is rated at 1,400 gpm @ 55 ft.

4. Variable Speed Drive Controls

- a. New variable speed drive motor controls are provided for each pump.
- b. Pump speed and pumping rate are automatically controlled by the liquid level in the wet well.
- c. Operation of one pump at full speed is required to pump the design maximum flow rate = 1,400 gpm = 2.00 MGD. Operation of two pumps at full speed is required to pump the peak flow rate of 2,800 gpm. The new third pump is provided as an installed standby pump.

5. Wet Well Liquid Level Control

- a. One liquid level sensor is provided in the pump station wet well to operate the pump station pump on, pump off and high liquid level alarm controls.
- b. A control system is provided to automatically adjust the pump operating speed and the flow pumping rate to maintain the liquid level in the pump station wet well.

H. 7 DAY FLOW EQUALIZATION BASIN ANOXIC REACTOR #1A & #1B (Existing)

1. Design Assumptions

a. Wastewater Flows

- 1) Maximum daily influent flow volume ≤ 2.00 MGD, 5 days/week.
- 2) Weekend flow approximately = $200,000 \text{ gpd} \times 2 \text{ days} = 400,000 \text{ gallons} \leq 0.40$ MG
- 3) Average daily effluent pumping rate required for 7 day hydraulic flow equalization =

$$\frac{2.00 \text{ MGD}(5 \text{ days}) + 0.20 \text{ MGD}(2 \text{ days})}{7 \text{ days}} = 1.50 \text{ MGD, 7 days/week}$$

b. Pollutant Concentrations and Loadings

- 1) The following influent wastewater pollutant concentrations and loadings are assumed in the design of the 7 Day FEB Anoxic Reactor #1A and FEB Anoxic Reactor #1B at the maximum influent wastewater flow volume ≤ 2.00 MGD from the upstream DAF pretreatment system:

Table #4
Pollutant Loadings in DAF Pretreatment System
Effluent at 2,000,000 gpd Wastewater Flow Volume

| Pollutant | Average | | Maximum | |
|-----------|---------------|-------------|---------------|-------------|
| | Concentration | Loading | Concentration | Loading |
| BOD | 600 mg/L | 10,000#/day | 800 mg/L | 13,344#/day |
| TSS | 100 mg/L | 1,668#/day | 150 mg/L | 2,502#/day |
| O&G | 60 mg/L | 1,000#/day | 100 mg/L | 1,668#/day |
| TKN | 75 mg/L | 1,251#/day | 125 mg/L | 2,085#/day |
| TP | 10 mg/L | 167#/day | 20 mg/L | 334#/day |

- c. FEB Reactor #1A and #1B are designed to function as anoxic (low DO) reactors operated in parallel to provide combined 7 day hydraulic flow equalization, carbonaceous BOD removal and nitrate nitrogen removal.

d. Emergency Wastewater Storage

In the event of power failure, wastewater can be stored in the 7 Day Flow Equalization Basin Reactors #1A and #1B until normal power is resumed.

2. Equalization Volume and Tank Volume Design Calculations

- a. Maximum volume required for 7 day, 24 hour hydraulic flow equalization =

$$(2.00 \text{ MGD} - 1.50 \text{ MGD})(5 \text{ days}) = 2.50 \text{ MG}$$

- b. Residual volume provided in FEB Reactor #1A and #1B at the 5.5 ft. low liquid depth = $0.72 \text{ MG}(2) = 1.44 \text{ MG}$

- c. Maximum volume provided in FEB Reactor #1A and #1B at the 11.5 ft. max. liquid depth = $2.00 \text{ MG}(2) = 4.00 \text{ MG}$.

3. 7 Day FEB/Reactors #1A & #1B BOD and Nitrate Removal Process Design

- a. FEB Reactor #1A and #1B are each constructed of a membrane lined, earthen basin that is 115 ft. long x 115 ft. wide (bottom dimensions) x 3/1 side slope x 13.5 ft. total depth x 12.0 ft. maximum liquid depth, 2.00 MG volume.

- b. The total maximum wastewater volume in both FEB Reactor #1A and #1B is approximately $2.00 \text{ MG} \times 2 = 4.0 \text{ MG}$ at the 12.0 ft. maximum operating liquid depth.

- c. The total minimum wastewater volume in both FEB Reactors #1A and #1B is approximately $0.72 \text{ MG} \times 2 = 1.44 \text{ MG}$ at the 5.5 ft. minimum operated liquid depth.

- d. 7 Day FEB Reactors #1A & #1B will be used for 7-day hydraulic flow equalization and also be operated in parallel as first stage anoxic activated sludge reactors for biological nitrate removal and carbonaceous BOD removal in a four stage biological nitrogen removal (BNR) system.

4. FEB Anoxic Reactors #1A & #1B Design

- a. Assume Anoxic FEB Reactors #1A & #1B will be used as an anoxic activated sludge reactor basin for removal of carbonaceous BOD in the pretreated wastewater discharged from the upstream DAF pretreatment cell, and, for removal of nitrate nitrogen contained in the mixed liquor flow recycled from downstream Nitrification Reactor #2A and #2B.

b. Calculate MLVSS concentration required for carbonaceous BOD removal by biological synthesis in FEB Reactors #1A & #1B at the minimum expected winter season design mixed liquor temperature of 15°C

1) For BOD removal assuming a carbonaceous BOD removal rate of 0.40# BOD/#MLVSS at 15°C and a carbonaceous BOD removal efficiency of 80%

$$\frac{13,344\#BOD/day (0.80)}{0.40} \leq 27,000\#MLVSS @ 15^\circ C$$

c. Calculate MLVSS concentration required for removal of nitrate nitrogen in the mixed liquor recycled from Nitrification Reactor #2.

1) Calculate TKN concentration and loading to be nitrified assuming a 3% nitrogen uptake rate for synthesis of carbonaceous BOD = 125 mg/L – 0.03 (800 mg/L) = 101 mg/L; TKN/day to be nitrified = (101 mg/L)(8.34)(2.00 MGD) = 1,685#TKN nitrified/day, 7 days/week.

2) Calculate the nitrate nitrogen in recycled mixed liquor assuming 100% of TKN into Nitrification Reactor #2 is nitrified, assuming a 100% sludge recycle rate from the Final Clarifier; and assuming a maximum nitrate recycle flow rate of 133% which = $\frac{1.33Q + 1Q(RAS)}{1Q + 1Q(RAS) + 4Q} = \frac{2.33Q}{6Q} = 0.34 = 40\%$ of the total flow rate that would be discharged from Nitrification Reactor #2.

$$\begin{aligned} \#NO_3-N \text{ recycled} &= 0.40 (1,685\#TKN/day) \\ &= 674\#NO_3-N/day \text{ denitrified} \end{aligned}$$

3) For NO₃-N removal assuming a denitrification rate ≥ 0.06# NO₃-N/#MLVSS at 15°C

$$\frac{674\#NO_3-N/day}{0.06} \leq 11,233\# MLVSS @ 15^\circ C$$

;therefore, #MLVSS for BOD removal governs the minimum biomass weight required and therefore the design MLVSS = 27,000# and #MLSS = 27,000/0.70 ≤ 39,000# assuming MLVSS/MLSS = 0.70

d. The maximum MLSS concentrations required in FEB Reactors #1A & #1B are calculated as follows at LWL and HWL

1) At LWL = 5.5 ft. when the effective anoxic basin volume is approximately 0.72 MGD(2) = 1.44 MG

$$\text{MLSS} = \frac{39,000\# \text{ MLSS}}{(1.44 \text{ MG})(8.34)} = 3,247 \text{ mg/L}$$

$$\leq 3,300 \text{ mg/L}$$

2) At HWL = 12.0 ft. when the effective anoxic basin volume is approximately 2.00 MG(2) = 4.00 MG

$$\text{MLSS} = \frac{39,000\# \text{ MLSS}}{(4.00 \text{ MG})(8.34)} = 1,170 \text{ mg/L}$$

$$\leq 1,200 \text{ mg/L}$$

e. Calculate the hydraulic detention time in FEB Anoxic Reactors #1A & #1B at LWL and HWL assuming the total flow volume into the anoxic reactor = 2.00 MGD inflow volume + 1Q RAS rate + 4Q nitrate mixed liquor recycle flow rate = 2.00 MGD + 2.00 MGD (RAS) + 2.00 MGD(4) = 12.0 MGD = 8,333 gpm

1) HDT(min) = $\frac{1,440,000 \text{ gallons}}{8,333 \text{ gpm}} = 172 \text{ min @ LWL}$

= 2.9 hrs @ LWL

2) HDT(aver) = $\frac{2,720,000 \text{ gallons}}{8,333 \text{ gpm}} = 326 \text{ min @ LWL}$

= 5.4 hrs @ LWL

3) HDT(max) = $\frac{4,000,000 \text{ gallons}}{8,333 \text{ gpm}} = 480 \text{ min @ HWL}$

= 8.0 hrs @ HWL

5. FEB Anoxic Reactor #1A & #1B Mixing and Aeration Equipment Design

a. Calculate the mixing requirements in 7 Day FEB Anoxic Reactors #1A & #1B:

1) BHP required for mixing 3,000 mg/L to 5,000 mg/L TSS concentration = 30 HP/MG using floating downpumping mixers.

- 2) Average normal operating liquid volume in FEB Reactor #1A and FEB Reactor #1B =

$$\frac{0.72 \text{ MG} + 2.00 \text{ MG}}{2} = 1.36 \text{ MG (per basin)} = 2.72 \text{ MG (total)}$$

- 3) Average BHP required = 30 HP(1.36 MG) ≤ 40 HP @ 8.75 ft. SWD
- 4) Maximum BHP required = 30 HP(2.00 MG) ≤ 60 HP @ 12.0 ft. SWD
- 5) One existing 40 HP floating, downpumping Aqua Aerobics mixer, and, a coarse bubble diffuser system is provided in each FEB Reactor basin for suspension and mixing of mixed liquor biomass solids.
- 6) One existing 7.5 HP floating, downpumping AerO₂ mixers is also provided in each FEB Reactor for additional mixing and oxygen transfer.

- b. Calculate the oxygen transfer rate required in FEB Anoxic Reactors #1A & #1B under normal operating conditions when the downstream Nitrification Reactor #2 is in service

- 1) Calculate the average and maximum oxygen transfer requirement for BOD synthesis assuming an oxygen demand = 0.60#O₂/#BOD and 80% BOD removal

$$\begin{aligned} \text{AOTR}_1 &= \frac{0.60\#O_2/\#BOD(13,344\#BOD/\text{day})(0.80)}{24} = 267\#O_2/\text{hr (max)} \\ &= \frac{0.60\#O_2/\#BOD(10,000\#BOD/\text{day})(0.80)}{24} = 200\#O_2/\text{hr (aver)} \end{aligned}$$

- 2) Calculate the average and maximum oxygen available in recycled nitrate for carbonaceous BOD removal in FEB Anoxic Reactor #1 assuming a nitrate recycle rate of 4Q = 133%; an RAS rate = 1Q = 100%; a recycled nitrate nitrogen fraction = 0.83 or 83%; and an oxygen supply of 2.86#O₂/#NO₃-N.

$$\text{AOTR}_2 = \#O_2 / \text{hr available from NO}_3\text{-N}$$

$$\begin{aligned} \text{AOTR}_2 &= \frac{(1,685\#\text{TKN}/\text{day nitrified})2.86(0.40)}{24} = -80\#O_2/\text{hr (max)} \\ &= \frac{(950\#\text{TKN}/\text{day nitrified})2.86(0.40)}{24} = -45\#O_2/\text{hr (aver)} \end{aligned}$$

- 3) Calculate the average and maximum oxygen transfer requirement for endogenous respiration where the average volume in FEB Reactors #1A and #1B is approximately 56% of the total activated sludge volume reactor volume calculated as follows:

| Reactor | Average Volume | % of Total Volume |
|---------------------------|----------------|-------------------|
| FEB Reactors #1A & #1B | 2.72 MG | 56% |
| Nitrification Reactor #2A | 1.64 MG | 34% |
| Nitrification Reactor #2B | 0.49 MG | 15% |
| Total Reactor Volume | 4.85 MG | 100% |

$$\begin{aligned}
 AOTR_3 &= \frac{(13,344 \# BOD / day)(0.80 \# O_2 / \# BOD)(0.56)}{24} = 249 \# O_2 / hr(\max) \\
 &= \frac{(10,000 \# BOD / day)(0.80 \# O_2 / \# BOD)(0.56)}{24} = 186 \# O_2 / hr(aver)
 \end{aligned}$$

- 4) Calculate the total amount of oxygen required in FEB Reactors #1A and #1B:

$$\begin{aligned}
 AOTR_{(total)} &= AOTR_1 - AOTR_2 + AOTR_3 \\
 &= 267 \# O_2 / hr - 80 \# O_2 / hr + 249 \# O_2 / hr = 436 \# O_2 / hr (\max) \\
 &= 200 \# O_2 / hr - 45 \# O_2 / hr + 186 \# O_2 / hr = 341 \# O_2 / hr (aver)
 \end{aligned}$$

- 5) Calculate the required corresponding standard oxygen transfer rate required:

$$SOTR = AOTR \left[\frac{C_{ss}}{(\beta C_{sw} - DO)\alpha(1.024)^{T-20}} \right]$$

Where DO \leq 0.30 mg/L (maximum D.O. in FEB Reactor #1A &

#1B)

$$\beta = 0.90$$

$$\alpha = 0.80 \text{ @ } 3,000 \text{ to } 5,000 \text{ mg/L MLSS with subsurface coarse bubble aeration diffusers}$$

$$1.024^{(T-20)} = 1.268 \text{ @ } T = 30^\circ C$$

$$C_w = 7.63 \text{ mg/L @ sea level, } 30^\circ\text{C @ max. mixed liquor temperature}$$

$$C_s = 9.20 \text{ mg/L @ sea level, @ } 20^\circ\text{C}$$

$$\text{Site Altitude} \leq 500 \text{ feet}$$

$$\text{Pressure Correction Factor} \geq 0.98$$

$$C_{sw} = 8.38 \left[\frac{(0.98)(14.7) + (0.5)(0.433)(8.75)^*}{14.7} \right]$$

$$= 8.38 \text{ mg/L}(1.109) = 9.29 \text{ mg/L}$$

$$C_{ss} = 9.20 \left[\frac{14.7 + (0.5)(0.433)(8.75)^*}{14.7} \right]$$

$$= 9.20 \text{ mg/L}(1.129) = 10.39 \text{ mg/L}$$

* Average FEB Reactor basin liquid depth = 8.75 ft.

$$\text{SOTR} = \text{AOTR} \frac{10.39}{\{(0.90)(9.29) - 0.3\} 0.80(1.268)}$$

$$\text{SOTR} = 1.27(\text{AOTR})$$

$$\text{SOTR} \leq 1.27(436) \leq 553 \# \text{O}_2/\text{hr (max)}$$

$$\leq 1.27(341) \leq 433 \# \text{O}_2/\text{hr (max)}$$

6) Calculate subsurface aeration equipment air sparging requirements:

a) The oxygen available per cfm per hour @ 20°C and 1 atm

$$x = 0.23 (0.075 \#/\text{ft}^3)(60 \text{ min/hr})$$

$$= 1.035 \# \text{O}_2/\text{cfm/hr}$$

b) e = subsurface diffuser oxygen stripping or transfer efficiency at maximum liquid depth = 12.0 ft. = 10%

$$\text{c) scfm required} = \frac{\text{SOTR}}{(1.035)(0.10)}$$

$$\begin{aligned} \text{scfm} &= \frac{553\#O_2/\text{HR}}{(1.035)(0.10)} && \leq 5,400 \text{ scfm (max)} \\ &= \frac{433\#O_2/\text{HR}}{(1.035)(0.10)} && \leq 4,200 \text{ scfm (aver)} \end{aligned}$$

d) The maximum blower pressure for aeration diffusers with maximum air sparge submergence = 12.0 ft. maximum liquid depth – 1.0 ft. diffuser elevation above floor = 11.0 ft. is calculated as follows:

$$= (11.0 \text{ ft.})(0.433) + 1.0 \text{ psi} = 5.8 \leq 6.0 \text{ psi including pressure loss in air supply lines and in jet nozzle diffusers}$$

- 7) Oxygen transfer in FEB Reactors #1A & #1B is provided by an existing air-grid coarse bubble diffused aeration headers installed approximately 1.0 ft. above the basin floor. Mixing can be provided in the Reactors with aeration and oxygen transfer by operation of 1 – 40 HP floating mixer in each Reactor basin. The total air sparging capacity of the coarse bubble diffuser system in the two FEB Reactor basins is approximately 5,400 scfm providing an oxygen transfer rate $\geq 400\#O_2/\text{hr}$ (AOTR) with air supplied by 3 – 75 HP positive displacement blowers each rated at 1,800 scfm at 5.75 psi.
- 8) Oxygen in Anoxic Activated Sludge Reactors #1A and #1B will normally be provided by nitrate oxygen contained in the mixed liquor recycle by gravity from the exiting downstream Nitrification Reactor #2A. Normally one air supply blower will be operated to provide compressed air flow to the coarse bubble diffusers in both FEB Reactor to provide supplemental mixing and some oxygen transfer to prevent septic conditions and odors.

6. Expected Effluent Quality at the Maximum 7 Day Discharge Flow Volume = 1.50 MGD

- a. To insure a conservative design approach due to large liquid level variation required in the FEB Anoxic Reactors #1A and #1B to accomplish 7 day hydraulic flow equalization, the following maximum Reactor #1A and #1B effluent pollutant concentrations and loadings are assumed for the design of downstream Nitrification Reactors #2A and #2B at the maximum average daily influent flow volume of 1.50 MGD and daily influent flow volume of 2.00 MGD:

| Pollutant | Average Concentration | Maximum Loading | Average Loading |
|--------------------|--------------------------------|-----------------|-----------------|
| BOD | $800(0.20) = 160 \text{ mg/L}$ | 2,668#/day | 2,002#/day |
| O&G | $100(0.20) = 20 \text{ mg/L}$ | 334#/day | 250#/day |
| TKN | 101 mg/L ⁽¹⁾ | 1,685#/day | 1,263#/day |
| NH ₃ -N | 50 mg/L ⁽²⁾ | 834#/day | 626#/day |
| TP | 16.0 mg/L ⁽³⁾ | 267#/day | 200#/day |

⁽¹⁾TKN = 175 mg/L – 0.03(800 mg/L BOD) = 101 mg/L

⁽²⁾NH₃-N will rise from 20 mg/L up to approximately 50 mg/L in the FEB Reactors

⁽³⁾TP = 20 mg/L – 0.005(800 mg/L BOD) = 16.0 mg/L

I. FEB ANOXIC REACTOR EFFLUENT PUMP STATION (Modification)

1. Design Assumptions

- a. Maximum Average Wastewater Flow Rate = $Q = 1.50 \text{ MGD} = 1,050 \text{ gpm}$, 24 hours/day, 7 days/week
- b. Maximum Wastewater Flow Rate = $Q(\text{max}) = 2.00 \text{ MGD} = 1,400 \text{ gpm}$, 24 hours/day, 5 days/week
- c. Maximum Nitrate Recycle Flow Rate = $260\% = 2.6Q = 2.6(2.00 \text{ MGD}) = 5.2 \text{ MGD} = 3,600 \text{ gpm}$, 24 hours/day
- d. Maximum Total Pumping Rate required without Return Activated Sludge Flow into FEB Reactor #1A and #1B = $1Q \text{ flow rate} + 2.6Q \text{ nitrate recycle rate} = 2.6Q = 3.6(2.00 \text{ MGD}) \leq 7.2 \text{ MGD} = 5,000 \text{ gpm}$, 24 hours/day
- e. Average Total Pumping Rate required = $2Q = 2(1.50 \text{ MGD}) = 3.0 \text{ MGD} = 2,100 \text{ gpm}$, 24 hours/day, 7 days/week

2. Pump Selection

- a. Two new 125 HP, 12” self-priming pumps are provided in the FEB Reactor Effluent Pump Station.
- b. Each pump is rated at 2,500 gpm @ 126 ft. total head when operated at full speed.
- c. Operation of two 12” self-priming pumps in parallel is required to provide the maximum total feed forward pumping capacity required = $1Q + 2.6Q$ (Nitrate Recycle) = $3.6Q = 3.6(2.00 \text{ MGD}) = 7.2 \text{ MGD} = 5,000 \text{ gpm} = 2,500 \text{ gpm/pump}$.

3. Variable Speed Drive Controls

- a. Each pump is provided with new variable speed drive motor controls operated by a manually adjustable constant flow sensor-controller for the effluent pumping rate from FEB Reactors #1A and #1B into the Nitrification Reactor #2A.
- b. The operator can manually select and set the desired effluent pumping rate and rely on the flow controller to automatically control and maintain the required pump speed to provide the selected flow pumping rate measured by the downstream magnetic flow meter.

4. Discharge Flow Meter

- a. Two new 16” dia. magnetic flow meter is provided in the new pump station discharge header to accurately measure, indicate, totalize, and allow manual control of the flow rate and volume pumped from FEB Anoxic Reactors #1A and #1B to Nitrification Reactor #2A.
- b. The flow meter can be used in combination with downstream flow control valve to maintain a desired set point flow rate from FEB Anoxic Reactors #1A and #1B into Nitrification Reactor #2A in the event automatic flow control is out of service, or manual flow control is preferred.

5. Emergency High Liquid Level Overflow

- a. One new emergency high liquid level overflow pipe is provided for gravity flow capability from FEB Reactor #1A into the adjacent stormwater collection lagoon in the event of FEB Reactor#1A and #1B Effluent Pump Failure, or, in the event of an inadequate pumping rate from FEB Reactor #1B into Reactor #2A.

J. NITRIFICATION REACTOR #2A & #2B (Existing & New)

1. General Description

- a. One existing 100 ft. dia. x 28 ft. liquid depth, 1.64 MG volume and one existing 81 ft. dia. x 12.75 ft. liquid depth, 0.49 MG volume above grade bolted carbon steel tanks are provided to be operated in series as a second stage, aerobic, activated sludge Nitrification Reactors #2A and #2B to provide ammonia removal by biological nitrification.
- b. Nitrification Reactors #2A & #2B can also be operated to provide complete single stage BOD and Ammonia removal in the event that FEB Reactors #1A and #1B must be taken out-of-service if the upstream DAF Pretreatment System is operated with higher efficiency chemical coagulation and flocculation to reduce BOD down to ≤ 350 mg/L and TKN down to ≤ 75 mg/L.

2. Design Assumptions

a. Wastewater Flow

- 1) Maximum average daily influent wastewater flow volume = 1.50 MGD, 7 days/week
- 2) Maximum daily influent wastewater flow volume = 2.00 MGD

b. Pollutant Concentrations and Loadings

- 1) Influent pollutant concentrations and loadings in the FEB Reactor #1B effluent maximum daily wastewater flow volume @ 2.00 MGD:

| Pollutant | Concentration | Maximum Loading |
|--------------------|----------------------|------------------------|
| BOD | 160 mg/L | 2,668#/day |
| TSS (MLSS) | 3,000 to 5,000 mg/L | ----- |
| O&G | 20 mg/L | 334#/day |
| TKN | 101 mg/L | 1,685#/day |
| NH ₃ -N | 50 mg/L | 834#/day |
| TP | 16.0 mg/L | 267#/day |

- 2) Influent pollutant concentrations and loadings in the FEB Reactor #1B effluent average daily wastewater flow volume @ 1.50 MGD:

| Pollutant | Concentration | Average Loading |
|--------------------|---------------------|-----------------|
| BOD | 160 mg/L | 2,002#/day |
| TSS (MLSS) | 3,000 to 5,000 mg/L | ----- |
| O&G | 20 mg/L | 250#/day |
| TKN | 101 mg/L | 1,263#/day |
| NH ₃ -N | 50 mg/L | 626#/day |
| TP | 16.0 mg/L | 200#/day |

3. Nitrification Reactors #2A and #2B Process Design (Winter Conditions)

- a. Calculate MLVSS and MLSS concentrations required for BOD and ammonia removal at the expected minimum winter season design mixed liquor temperature in Reactors #2A and #2B = 12°C

- 1) For BOD removal assuming a carbonaceous BOD removal rate = 0.33#BOD/# MLVSS @ 12°C:

$$\frac{2,668\#\text{BOD}/\text{day}}{0.33} \leq 8,085\#\text{ MLVSS @ }12^{\circ}\text{C}$$

- 2) For TKN removal assuming a nitrification rate of 0.04#TKN/# MLVSS at 12°C:

$$\frac{1,685\#\text{TKN}/\text{day}}{0.04} \leq 42,125\#\text{MLVSS @ }12^{\circ}\text{C}$$

- 3) The required MLVSS and MLSS concentrations in the total reactor volume for BOD removal and nitrification at the 12°C minimum winter season operating temperature assuming MLVSS/MLSS = 0.70

$$\frac{8,085\# + 42,125\#}{(8.34)(1.64\text{ MG} + 0.49\text{ MG})} =$$

$$\frac{50,210\#\text{MLVSS}}{(8.34)(2.13\text{ MG})} = 2,826\text{ mg/L MLVSS}$$

$$\frac{2,826\text{ mg/L}}{0.70} = 4,037\text{ mg/L MLSS}$$

$$\leq 5,000 \text{ mg/L} \pm \text{MLSS}$$

Assume MLSS $\leq 5,000 \text{ mg/L}$ in Nitrification Reactor #2A and #2B during **winter season** for conservative design approach.

- 4) If the MLSS concentration in Nitrification Reactors #2A and #2B is $5,000 \text{ mg/L}$, then the MLSS concentration in FEB Anoxic Reactors #1A and #1B will be approximately $5,000 \text{ mg/L}$ if return sludge is pumped back into FEB Reactors #1A and #1B

4. Nitrification Reactors #2A and #2B Process Design (Summer Conditions)

- a. Calculate MLVSS and MLSS concentrations required for BOD and ammonia removal at the expected average summer season design mixed liquor temperature in Reactors #2A & #2B = 22°C

- 1) For BOD removal assuming a carbonaceous BOD removal rate = $0.45 \# \text{ BOD}/\# \text{ MLVSS @ } 22^\circ\text{C}$:

$$\frac{2,668 \# \text{ BOD/day}}{0.45} \leq 5,929 \# \text{ MLVSS @ } 22^\circ\text{C}$$

- 2) For TKN removal assuming a nitrification rate of $0.06 \# \text{ TKN}/\# \text{ MLVSS}$ at 22°C :

$$\frac{1,685 \# \text{ TKN/day}}{0.06} \leq 28,083 \# \text{ MLVSS @ } 22^\circ\text{C}$$

- 3) The required MLVSS and MLSS concentrations in the total reactor volume for BOD removal and nitrification at the 22°C average summer season operating temperature assuming MLVSS/MLSS = 0.70

$$\frac{5,929 \# + 28,083 \#}{(8.34)(1.64 \text{ MG} + 0.49 \text{ MG})} =$$

$$\frac{34,012 \# \text{ MLVSS}}{(8.34)(2.13 \text{ MG})} = 1,915 \text{ mg/L MLVSS}$$

$$\frac{1,915 \text{ mg/L}}{0.70} = 2,735 \text{ mg/L MLSS}$$

$$\leq 3,000 \text{ mg/L} \pm \text{MLSS @ } 22^\circ\text{C}$$

Assume MLSS $\leq 3,000 \text{ mg/L}$ in Nitrification Reactor #2 during **summer season** for conservative design approach.

- 4) If the MLSS concentration in Nitrification Reactor #2 is 3,000 mg/L then the MLSS concentration in FEB Anoxic Reactor #1 will be approximately 3,000 mg/L if return sludge is pumped back into FEB Reactors #1A and #1B.
5. Calculations indicate that the existing 1.64 MG volume Reactor #2A and existing 0.49 MG volume Reactor #2B will be of adequate total volume for accomplishing the required winter season BOD and TKN (ammonia) removal. The use of subsurface jet aeration equipment in Reactor #2A and coarse bubble diffusers in Reactor #2B will insure maximum operating temperatures in the activated sludge treatment process during the winter season. If winter season aeration basin mixed liquor temperatures cannot be maintained at approximately 12°C, then to achieve adequate TKN removal efficiency, the MLSS concentration can be increased above 5,000 mg/L and/or upstream pretreatment efficiency must be improved by increased chemical dosage in DAF Cell to reduce the TKN loading on the downstream multi-stage activated sludge treatment system.
6. Nitrification Reactors #2A and #2B Mixing Equipment Design
 - a. Evaluate mixing requirements in Nitrification Reactors #2A and #2B:
 - 1) bhp required for mixing a 3,000 to 5,000 mg/L MLSS concentration = 40 HP/MG using directional mix jet aeration manifold in Reactor #2A.

bhp required = 40 HP (1.64) ≤ 65 HP in Reactor #2A
 - 2) One existing 75 HP jet recirculation pump and one directional mix jet aeration header is provided in Nitrification Reactor #2A tank for suspension and mixing of mixed liquor biomass solids. One new ____ HP self-priming jet recirculation pump and one directional mix jet aeration header is provided in Nitrification Reactor #2A for supplemental mixing and oxygen transfer capacity.
 - 3) cfm required for complete mixing of Reactor #2B at 3,000 mg/L to 5,000 mg/L MLSS concentration = 15 to 20 scfm/1,000 ft³ with reactor volume = 0.49 MG = 65 x 10³ ft³

scfm = (65)(15 to 20 scfm) ≤ 1,300 scfm in Reactor #2B
 - 4) One existing coarse bubble diffuser system is provided in Nitrification Reactor #2B for diffusing air for suspension and mixing of mixed liquor biomass solids.

7. Nitrification Reactor #2A & #2B Aeration Equipment Design

- a. Calculate the maximum and average oxygen transfer rate required in Nitrification Reactors #2A and #2B:

- 1) Calculate the oxygen transfer requirement for BOD synthesis assuming 80% BOD removal in FEB upstream Anoxic Reactors #1A & #1B:

$$AOTR_1 = \frac{(0.60 \#O_2/\#BOD/day)(2,668 \#BOD/day)}{24} = 67 \#O_2/hr \text{ (max)}$$

$$AOTR_1 = \frac{(0.60 \#O_2/\#BOD/day)(2,002 \#BOD/day)}{24} = 50 \#O_2/hr \text{ (aver)}$$

- 2) Calculate the oxygen transfer requirement for nitrification:

$$AOTR_2 \leq \frac{(4.57 \#O_2/\#TKN)(1,685 \#TKN/day \text{ nitrified})}{24} = 321 \#O_2/hr \text{ (max)}$$

$$AOTR_2 \leq \frac{(4.57 \#O_2/\#TKN)(1,263 \#TKN/day \text{ nitrified})}{24} = 240 \#O_2/hr \text{ (aver)}$$

- 3) Calculate the oxygen transfer requirement for endogenous respiration where Nitrification Reactor #2A and #2B total volume is approximately 44% of the total activated sludge volume:

$$AOTR_3 = \frac{(13,344 \#BOD/day)(0.80 \#O_2/\#BOD)(0.44)}{24} = 196 \#O_2/hr \text{ (max)}$$

$$AOTR_3 = \frac{(10,000 \#BOD/day)(0.80 \#O_2/\#BOD)(0.44)}{24} = 147 \#O_2/hr \text{ (max)}$$

- 4) Calculate the total maximum and average oxygen transfer rate required in Nitrification Reactors #2A & #2B:

$$\begin{aligned} AOTR(\text{total}) &\leq AOTR_1 + AOTR_2 + AOTR_3 \\ &= 67 \#O_2/hr + 321 \#O_2/hr + 196 \#O_2/hr = 584 \#O_2/hr < 600 \#O_2/hr \text{ (max)} \\ &= 50 \#O_2/hr + 240 \#O_2/hr + 147 \#O_2/hr = 437 \#O_2/hr < 450 \#O_2/hr \text{ (aver)} \end{aligned}$$

Assume 80% to 90% of total oxygen demand occurs in Reactor #2A, and, 10% to 20% of total oxygen demand occurs in Reactor #2B

$$AOTR \text{ #2A} \leq 600 \#O_2/hr(0.90) \leq 540 \#O_2/hr \text{ (max)}$$

$$AOTR \text{ #2B} \leq 600 \#O_2/hr(0.20) \leq 120 \#O_2/hr \text{ (max)}$$

$$AOTR \text{ #2A} \leq 450 \#O_2/hr(0.90) \leq 405 \#O_2/hr \text{ (aver)}$$

$$AOTR \text{ #2B} \leq 450 \#O_2/hr(0.20) \leq 90 \#O_2/hr \text{ (aver)}$$

- 5) Calculate the required corresponding maximum standard oxygen transfer rate required:

$$SOTR = AOTR \left[\frac{C_{ss}}{(\beta C_{sw} - DO) \alpha (1.024)^{T-20}} \right]$$

| | | |
|----------------------------|---|--|
| Where DO | ≤ | 2.0 mg/L (average DO in Reactor #2) |
| β | = | 0.90 |
| α | = | 0.80 @ 3,000 to 5,000 mg/L MLSS with subsurface jet aeration manifolds |
| Maximum MLSS temperatures | = | 30°C |
| 1.024 ^(T-20) | = | 1.2677 @ T = 30°C |
| C _w | = | 7.63 mg/L @ sea level, 30°C |
| C _s | = | 9.20 mg/L @ sea level, 20°C |
| Site Altitude | ≤ | 500 feet |
| Pressure Correction Factor | ≥ | 0.98 |

$$C_{sw} = 7.63 \left[\frac{(0.98)(14.7) + (0.5)(0.433)(28)^*}{14.7} \right]$$

$$= 7.63 (1.392) = 10.62 \text{ mg / L}$$

$$C_{ss} = 9.20 \left[\frac{(14.7) + (0.5)(0.433)(28)^*}{14.7} \right]$$

$$= 9.20 (1.412) = 12.99 \text{ mg / L}$$

* Reactor liquid depth = 28 ft.

$$SOTR = AOTR \frac{12.99}{[(0.90)(10.62) - 2.0]0.80(1.2677)}$$

$$SOTR = 1.68(AOTR)$$

$$\text{SOTR \#2A} \leq 1.70(540\#O_2/\text{hr}) \leq 925\#O_2/\text{hr} \text{ (maximum)}$$

$$\text{SOTR \#2B} \leq 1.70(120\#O_2/\text{hr}) \leq 225\#O_2/\text{hr} \text{ (maximum)}$$

$$\text{SOTR \#2A} \leq 1.70(405\#O_2/\text{hr}) \leq 700\#O_2/\text{hr} \text{ (average)}$$

$$\text{SOTR \#2A} \leq 1.70(90\#O_2/\text{hr}) \leq 155\#O_2/\text{hr} \text{ (average)}$$

b. Calculate subsurface aeration equipment air sparging requirements:

1) The oxygen available per cfm per hour =

$$x = 0.23 (.075\#/ft^3)(60 \text{ min/hr})$$

$$= 1.035\#O_2/\text{cfm/hr} @ 68^\circ\text{C inlet air}$$

2) e = subsurface coarse bubble diffuser oxygen stripping or transfer efficiency at 28 ft. liquid depth = 37% in Reactor #2A

e = subsurface coarse bubble diffuser oxygen stripping or transfer efficiency at 12.75 ft. liquid depth = 9% in Reactor #2B

3) scfm required = $\frac{\text{SOTR}}{(x)(e)}$

$$\text{scfm \#2A} = \frac{925\#O_2/\text{hr}}{(1.035)(0.37)} = 2,415 \text{ scfm} \leq 2,500 \text{ scfm (max)}$$

$$\text{scfm \#2B} = \frac{225\#O_2/\text{hr}}{(1.035)(0.09)} = 988 \text{ scfm} \leq 2,500 \text{ scfm (max)}$$

$$\text{scfm \#2A} = \frac{700\#O_2/\text{hr}}{(1.035)(0.37)} = 1,827 \text{ scfm} \leq 1,900 \text{ scfm (aver)}$$

$$\text{scfm \#2B} = \frac{153\#O_2/\text{hr}}{(1.035)(0.09)} = 1,643 \text{ scfm} \leq 1,700 \text{ scfm (aver)}$$

4) Max. design blower pressure in Reactor #2A at 28.0 – 3.50 = 24.5 ft. jet diffuser air sparge submergence with existing jet manifold located 42" above the reactor floor:

$$= (24.5 \text{ ft.})(0.433) + 1.00 \text{ psi} = 11.6 \text{ psi} \leq 11.6 \text{ psi including pressure drop in air supply lines and in jet nozzle diffusers}$$

Max. design blower pressure in Reactor #2B at $12.75 - 1.00 = 11.75$ ft. diffuser air sparge submergence with coarse bubble diffusers located approximately 1.0 ft. above the reactor floor:

$$= (11.75 \text{ ft.}) (0.433) + 1.00 \text{ psi} = 6.1 \text{ psi} \leq 6.5 \text{ psi including pressure drop in air supply lines and in diffusers}$$

- c. Oxygen transfer and mixing is provided in Nitrification Reactor #2A by operation of one existing directional mix subsurface jet aeration manifold with 22 jet nozzles. Flow recirculation for the jet manifold is provided by one existing 75 HP end suction sewage pump rated at 8,000 gpm at 25 ft. The jet pump has a constant speed drive motor. The design air sparging capacity of the jet aeration manifold is approximately 2,475 scfm providing an oxygen transfer rate = $500\#O_2/\text{hr}$ (AOTR) = $800\#O_2/\text{hr}$ (SOTR) with air supplied by one existing 250 HP centrifugal blower rated at approximately 3,000 scfm at 11.5 psi. A second 250 HP centrifugal blower is provided as an installed standby.
- d. **One new drop in, wet installed directional mix slot jet aeration manifold will be installed in Nitrification Reactor #2A to provide additional oxygen transfer capacity. The slot jet aeration manifold includes one new 75 HP self-priming pump for jet flow recirculation rated at 2,800 gpm @ 50 ft. One new 125 HP positive displacement blower is also provided with the jet manifold for compressed air supply. The new blower is rated at 1,244 scfm @ 12.5 psi. Operation of the jet manifold at 1,244 scfm will provide an additional oxygen transfer capacity = $350\#O_2/\text{hr}$ (AOTR) = $530\#O_2/\text{hr}$ (SOTR).**
- e. **Oxygen transfer and mixing is provided in Nitrification Reactor #2B by and existing coarse bubble diffuser system. The maximum air sparging capacity of the diffusers is approximately 3,400 scfm providing an oxygen transfer rate $\geq 200\#O_2/\text{hr}$ (AOTR) with air supplied by two existing 75 HP centrifugal blowers in operation each rated at 1,700 scfm at 6.0 psi. The average air sparging capacity of the diffusers is approximately 1,700 scfm providing an oxygen transfer rate $\geq 100\#O_2/\text{hr}$ (AOTR) with air supplied by one 75 HP blower in operation. A third 75 HP blower is provided as an installed standby.**
- f. If Nitrification Reactor #2A is removed from services a maximum air sparging capacity of 4,400 scfm providing an oxygen transfer rate of $\geq 600 \#O_2/\text{hr}$ (AOTR) through the Nitrification Reactor #2B coarse bubble diffuser system. Air will be supplied by operation of one new 100 HP blower rated at 1,000 scfm at 11.6 psi and the two spare 150 HP blowers for the FEB (one spare blower) and the Waste Activated Sludge Storage Tank (one spare blower) each rated at 1,700 scfm at 12 psi.

g. In Reactor #2A:

- 1) The maximum oxygen transfer rate provided in Reactor #2A by operation of 1-75 HP jet pump and 1-200 HP centrifugal blower $\geq 800\#O_2/hr$ (SOTR) = $500\#O_2/hr$ (AOTR).
- 2) The maximum additional oxygen transfer capacity provided in Reactor #2A by operation of the new directional mix slot jet header with 1-75 HP jet pump and 1-125HP blower in operation = $350\#O_2/hr$ (AOTR). The total maximum oxygen transfer capacity provided in Reactor #2A = $500\#O_2/hr + 350\#O_2/hr = 850\#O_2/hr$ (AOTR).

h. In Reactor #2B:

- 1) The maximum oxygen transfer rate provided in Reactor #2B by operation of 2-75 HP centrifugal blowers = $200\#O_2/hr$ (AOTR).
 - 2) The average oxygen transfer rate provided in Reactor #2B by operation of 1-75 HP positive displacement blower = $100\#O_2$ (AOTR).
- i. The maximum total oxygen transfer capacity provided by operation of the existing jet aeration manifold and one 250 HP centrifugal blower, the new jet aeration manifold and one 125 HP positive displacement blower for Reactor #2A; and, the diffusers and two blowers for Reactor #2B = $850\#O_2/hr + 200\#O_2/hr = 1,050\#O_2/hr$.
- j. The average total oxygen transfer capacity provided by operation of the existing jet aeration manifold and one centrifugal blower for Reactor #2A; and, the new diffusers and one PD blower for Reactor #2B = $500\#O_2/hr + 100\#O_2/hr = 600\#O_2/hr$.

K. CLARIFIER INFLUENT FLOW SPLITTER & FLOCCULATION TANK FOR CLARIFIERS #1 (Existing) & #2 (New)

1. Design Assumptions

a. Wastewater Flow

- 1) Average throughput flow = 1.50 MGD, 7 days/week
- 2) Maximum daily throughput flow volume = 2.00 MGD
- 3) Maximum inflow rate with 100% sludge recycle rate = $(2.00\text{ MGD})(2) \leq 4.00$ MGD

4) Maximum inflow rate with 150% sludge recycle rate = $(2.00 \text{ MGD})(2.5) \leq 5.00 \text{ MGD}$

b. Mixed Liquor Suspended Solids Concentrations

1) Minimum MLSS = 3,000 mg/L

2) Maximum MLSS = 5,000 mg/L

2. General Description

a. One existing clarifier influent flow splitter tank is provided in the outlet of Reactor #2B to split flow into existing Final Clarifier #1 and new Final Clarifier #2.

b. The flow splitter tank will function as a flocculation tank for dosage and mixing of coagulant and flocculant chemical solutions with the clarifier influent mixed liquor flow.

3. Flocculation Tank Design Calculations

a. Flocculation Tank Sizing

1) One 8.0 ft. dia. x 11 ft. side water depth Flocculation Tank is provided for mixing of chemical coagulant and flocculant solutions and the mixed liquor influent flow into Final Clarifiers #1 and #2.

2) Tank volume \geq 4,000 gallons

3) Calculated Hydraulic Detention Times:

a) @ 2.00 MGD maximum design flow through rate plus 100% sludge return flow rate = 4.00 MGD = 2,800 gpm total flow rate = 2.00 MGD/clarifier = 1,400 gpm/clarifier

$$\text{HDT} = \frac{4,000 \text{ gallons}}{1,400 \text{ gpm}} = 2.8 \text{ minutes}$$

b) @ 2.00 MGD maximum design flow through rate plus 150% sludge return flow rate = 5.00 MGD = 3,500 gpm total flow rate = 2.50 MGD/clarifier = 1,735 gpm/clarifier

$$\text{HDT} = \frac{4,000 \text{ gallons}}{2,100 \text{ gpm}} = 1.9 \text{ minutes}$$

L. FINAL CLARIFIER (Existing & New)

1. Design Assumptions

a. Wastewater Flow Volumes

- a. Average throughput flow = 1.50 MGD, 7 days/week
- b. Maximum throughput flow = 2.00 MGD
- c. Average inflow rate with 100% sludge recycle rate = $(1.50 \text{ MGD})(2) \leq 3.00 \text{ MGD}$
- d. Maximum inflow rate with 150% sludge recycle rate = $(2.00 \text{ MGD})(2.5) \leq 5.00 \text{ MGD}$

b. MLSS Solids Concentrations

- 1) Average MLSS Concentration $\leq 3,000 \text{ mg/L}$
- 2) Maximum MLSS Concentration $\leq 5,000 \text{ mg/L}$

2. General Description

- a. One existing 81 ft. diameter x 10.5 ft. side water depth Final Clarifier #1; and, one new 81 ft. dia. x 12 ft. side water depth Final Clarifier #2, each with hydraulic suction sludge pickup mechanism, surface skimmer and two scum boxes are provided to operate in parallel for final clarification.
- b. Each clarifier has an effective surface overflow diameter = 78 feet, effective surface overflow area = $4,700 \text{ ft}^2$; and, effective clarifier floor area = $5,100 \text{ ft}^2$.

3. Calculate Clarifier Loading Rates

- a. Clarifier #1 volume = 404,000 gallons; and, Clarifier #2 volume = 460,000 gallons.

b. Hydraulic Surface Loading Rate:

$$= \frac{1,500,000 \text{ gpd}}{4,700 \text{ ft}^2(2)} \leq 160 \text{ gpd/ft}^2 \text{ @ avg. 7 day throughput flow rate} = 1.50 \text{ MGD}$$

$$= \frac{2,000,000 \text{ gpd}}{4,700 \text{ ft}^2(2)} \leq 215 \text{ gpd/ft}^2 \text{ @ max. throughput flow rate} = 2.00 \text{ MGD}$$

- c. Average solids loading rate assuming an influent flow rate = 1.50 MGD and a 100% sludge recycle rate with a MLSS concentration $\leq 5,000$ mg/L:

$$= \frac{(1.50)(2)(8.34)(5,000 \text{ mg/L})}{5,100 \text{ ft}^2(2)}$$

= 13.0#/ft²/day @ average inflow rate = 3.00 MGD including 100% sludge recycle flow

- d. Maximum solids loading rate assuming an influent flow rate = 2.00 MGD and a 150% sludge recycle rate with a MLSS concentration $\leq 5,000$ mg/L:

$$= \frac{(2.0)(2.5)(8.34)(5,000 \text{ mg/L})}{5,100 \text{ ft}^2(2)}$$

= 20.5#/ft²/day @ max. inflow rate = 5.00 MGD including 100% sludge recycle flow

- e. Average hydraulic detention time at 1.50 MGD average throughput flow volume assuming a 100% sludge recycle rate:

$$= \frac{(404,000 \text{ gal} + 460,000 \text{ gal})(24)}{(1,500,000)(2)}$$

= 6.9 hrs. @ average inflow rate = 3.00 MGD including 100% sludge recycle flow

Minimum hydraulic detention time @ 2.00 MGD maximum throughput flow volume assuming a 150% sludge recycle rate:

$$= \frac{(404,000 \text{ gal} + 460,000 \text{ gal})(24)}{(2,000,000)(2.5)}$$

= 4.1 hrs. @ max. inflow rate = 4.00 MGD including 100% sludge recycle flow.

M. RETURN ACTIVATED SLUDGE (RAS) PUMP STATION (Modification)

1. Flow Pumping Requirements

- a. The average RAS pumping rate required from Clarifier #1 = 50% of the maximum daily throughput flow volume = $(0.50)(2.00 \text{ MGD}) = 1.00 \text{ MGD} = 700 \text{ gpm}$ with one RAS pump in operation for Clarifier #1.
- b. The maximum RAS pumping rate required from Clarifier #1 = 200% of the maximum daily throughput flow volume = $(2)(2.00 \text{ MGD}) = 4.00 \text{ MGD} = 2,800 \text{ gpm}$ with two RAS pumps in operation for Clarifier #1.

- c. The average RAS pumping rate required from Clarifier #2 = 50% of the maximum daily throughput flow volume = $(0.50)(2.00 \text{ MGD}) = 1.00 \text{ MGD} = 700 \text{ gpm}$ with one RAS pump in operation for Clarifier #1.
- d. The maximum RAS pumping rate required from Clarifier #2 = 200% of the maximum daily throughput flow volume = $(2)(2.00 \text{ MGD}) = 4.00 \text{ MGD} = 2,800 \text{ gpm}$ with two RAS pumps in operation for Clarifier #1.

2. Pump Selection

- a. Two existing 20 HP self-priming sludge return pumps are provided in the existing Sludge Return Pump Station enclosure building located adjacent to the Final Clarifier #1. The pumps are provided to recycle activated sludge from the two clarifiers to Nitrification Reactor #2A. Each pump is currently rated at 470 gpm @ 35 feet head which is equivalent to a sludge recycle rate $\geq 33\%$ of the maximum throughput flow rate.
- b. Each RAS pump will be upgraded by installation of new larger 40 HP motor with new belts and sheaves in order to increase the pump rated flow capacity up to 1,400 gpm @ 45 feet which is equivalent to a sludge recycle rate = 100% of the maximum throughput flow rate = $(1.0)(2.00 \text{ MGD}) = 2.0 \text{ MGD} = 1,400 \text{ gpm}$.
- c. Each upgraded RAS pump will normally be operated at reduced speed to provide a separate sludge recycle rate from each clarifier = 25% to 50% of the maximum throughput flow rate = $0.25 (2.00 \text{ MGD})$ to $0.50 (2.00 \text{ MGD}) = 0.50 \text{ MGD}$ to $1.00 \text{ MGD} = 350 \text{ gpm}$ to 700 gpm per clarifier. Two RAS pumps can be operated at full speed in parallel to provide a total maximum sludge recycle rate from either Clarifier #1 or Clarifier #2 up to 200% of the maximum throughput flow rate = $2(2.00 \text{ MGD}) = 4.00 \text{ MGD} = 2,800 \text{ gpm}$ if one clarifier is out of service.
- d. RAS Pump #1 will normally be operated to provide sludge recycle from Clarifier #1 and RAS Pump #2 to provide sludge recycle from Clarifier #2.
- e. RAS Pump #1 and Pump #2 can be operated in parallel to provide sludge recycle from one Clarifier if the second Clarifier is out of service.

3. Variable Speed Drive Controls

- a. Each upgraded existing RAS Pump is provided with new variable speed drive motor controls to allow manual control of pump operating speed and pumping rate.
- b. The speed of each pump can be manually adjusted to provide an RAS flow rate ranging from 50% to 150%.

4. RAS Flow Meters

- a. One new 8” magnetic flow meter is provided in the RAS Pump Station to accurately measure and indicate the sludge recycle flow from Final Clarifier #1. RAS Flow Meter #1 is provided with a digital flow indicator and with a downstream flow control valve to allow the sludge recycle flow from the Clarifier #1 to be throttled and controlled.
- b. One new 8” magnetic flow meter is provided in the RAS Pump Station to accurately measure and indicate the sludge recycle flow from Final Clarifier #2. RAS Flow Meter #2 is provided with a digital flow indicator and with a downstream flow control valve to allow the sludge recycle flow from the Clarifier #2 to be throttled and controlled.

N. WASTE ACTIVATED SLUDGE (WAS) PUMP (New)

1. WAS Pump for Clarifier #1 and Clarifier #2 (New)

a. Flow Pumping Requirements

- 1) The average WAS pumping rate required = approximately 30 gpm
- 2) The maximum WAS pumping rate required = approximately 100 gpm

b. Pump Selection

- 1) One new 7.5 HP positive displacement WAS pump is provided rated at 100 gpm @ 60 ft. to pump WAS from the RAS suction line of Clarifier #1 and/or Clarifier #2. The new WAS pump is installed in the existing RAS Pump Station enclosure building.

c. Variable Speed Drive Controls

- 1) The pump is provided with variable speed drive motor controls to allow manual control of pump operated speed and pumping rate.

d. WAS Flow Meter

- 1) One existing 4” WAS magnetic Flow Meter is provided to measure, indicate and totalize the WAS pumping rate and volume from the RAS suction line of either of the two Final Clarifiers.

O. ULTRAVIOLET (UV) FINAL EFFLUENT DISINFECTION SYSTEM (New)

1. Design Assumptions

a. Wastewater Flows

- 1) Average daily throughput flow rate \leq 1.50 MGD = 1,050 gpm
- 2) Maximum daily throughput flow rate \leq 2.00 MGD – 1,400 gpm

b. Monthly Average Influent Pollutant Concentrations

| | | |
|-------------------|--------|----------|
| TSS | \leq | 2.0 mg/L |
| O&G | \leq | 1.0 mg/L |
| NH ₃ N | \leq | 1.0 mg/L |

c. Monthly Average Effluent Limitations

Enterococcus \leq 33 col/100 ml (Monthly Average)

2. In order to comply with the enterococcus bacteria limitations, final effluent will be disinfected by ultraviolet light (UV) to replace the existing chlorination and dechlorination system.

3. One new UV contact basin will installed for final effluent disinfection. The UV contact channel structure has the following dimensions and volume:

a. Concrete Channel Structure

- 1) Total Length = 30.0 ft.
- 2) Width = 1 ft.
- 3) Depth = 4.5 ft.

b. UV Lamp Bank Contact Zone

- 1) Number of UV Banks = 2
- 2) Contact Length/UV Bank = 8.60 ft.
- 3) Channel Width = 12 inches
- 4) Maximum Liquid Depth = 18 inches
- 5) Contact Zone Volume/UV Bank = 16.125 ft³ = 120 gallons

4. UV System Components and Design Features

a. UV Transmission = 60% minimum

- b. Minimum Detention Time through UV Contact Banks ≥ 5.4 seconds
- c. UV Dose - 62,800 microWatts/cm² at 60% minimum transmission.
- d. Uniform Lamp Array - 3 Banks each with 5 Modules per Bank and 6 lamps per module providing a total of 36 UV Lamps
- e. The UV system will have one Power Distribution Centers and one System Control Center.
- f. The discharge end of the UV Contact Channel will be provided with one fixed weir plate level controller
- g. The UV system is provided with an Automatic Chemical/Mechanical Cleaner
- h. Automatic Power Dose Pacing System Control is provided.

5. Emergency Disinfection

- a. If the UV equipment is out of service; or, if emergency effluent break point chlorination and dechlorination is required for ammonia removal, the existing chlorine contact basin can be operated for final effluent disinfection using sodium hypochlorite solution dosage for chlorination and sodium bisulfite solution dosage for dechlorination.

P. CHLORINE CONTACT BASIN (Existing)

- 1. UV disinfected effluent will flow through the existing chlorine contact basin to the existing effluent flow meter. In an emergency, sodium hypochlorite can be fed into the chlorine contact basin to provide disinfection.

- a. Total Length = 126.0 feet

Width = 5.0 feet in chlorination-dechlorination zone

Depth = 6.0 feet (increase depth approximately 1.0 ft. from present operating depth = 5.0 ft.)

Chlorination Zone Length = 117.0 ft.

Dechlorination Zone Length = 9.0 ft.

- b. Total Volume = $3,775 \text{ ft}^3 = 28,250$ gallons

Chlorination Zone Volume = $3,509.5 \text{ ft}^3 = 26,250$ gallons

Dechlorination Zone Volume = $267.5 \text{ ft}^3 = 2,000 \text{ gallons}$

2. Hydraulic Detention Time in Chlorination Zone

a. @ Average 7 day inflow rate = 1.50 MGD = 1,050 gpm

$$t = \frac{26,250 \text{ gallons}}{1,050 \text{ gpm}} = 25.0 \text{ minutes}$$

b. @ Maximum inflow rate = 2.00 MGD = 1,400 gpm

$$t = \frac{26,250 \text{ gallons}}{1,400 \text{ gpm}} = 18.75 \text{ minutes}$$

3. Hydraulic Detention Time in Dechlorination Zone

a. @ Average 7 day inflow rate = 1.50 MGD = 1,050 gpm

$$t = \frac{2,000 \text{ gallons}}{1,050 \text{ gpm}} = 1.9 \text{ minutes}$$

b. @ Maximum inflow rate = 2.00 MGD = 1,400 gpm

$$t = \frac{2,000 \text{ gallons}}{1,400 \text{ gpm}} = 1.4 \text{ minutes}$$

4. Contact Basin Cleaning

a. The contact basin is designed to be completely drained to allow for cleaning by opening of a gravity drain valve into the existing basin drain line.

Q. WASTE ACTIVATED SLUDGE PRODUCTION

1. Calculation of F/M_T Ratio of BNR Activated Sludge Treatment Process

a. Calculate F/M_T ratio at the design BOD loading rate based on the total activated sludge reactor volume = 2.72 MG average + 1.64 MG + 0.49 = 4.85 MG average, and, average MLSS concentration = 5,000 mg/L.

$$\begin{aligned} 1) \ F/M_T &= \frac{13,344 \# \text{BOD/day}}{(5,000 \text{mg/L})(4.85 \text{ MG})(8.34)} \\ &\leq 0.07 \# \text{BOD}/\# \text{MLSS} @ 5,000 \text{ mg/L} \end{aligned}$$

$$2) Y = \text{Expected activated sludge production rate @ } 0.07 \text{ F/M ratio} \leq 0.60 \text{ \# Sludge/\#BOD applied}$$

2. Calculation of Waste Sludge Production

- a. At the expected F/M ratio of 0.07 #BOD/#MLSS, biosolids sludge must be wasted at a rate of under 0.60 #TSS/#BOD applied from the activated sludge treatment system. At the design maximum BOD load of 13,344 #BOD/day approximately $13,344(0.60 \text{ \#TSS/\#BOD}) = 8,000 \text{ \#/day}$ (dry basis) of activated sludge biosolids must be wasted from the activated sludge process each day to maintain the correct MLSS concentration in the multi-stage activated sludge treatment process. Activated sludge will be wasted by being pumped from the Final Clarifier sludge return pump station to the new WAS Storage Tank (SST) for aerobic digestion, gravity thickening, decanting and storage prior mechanical dewatering and being hauled to a land application site for ultimate disposal.
- b. The dosage of aluminum chloride or aluminum sulfate coagulant solution into the Final Clarifier influent mixed liquor flow is required to achieve phosphorus removal by chemical precipitation of orthophosphate contained in the wastewater followed by sedimentation of precipitated solids in the Final Clarifiers. This continuous chemical precipitation process will result in the production of additional chemical sludge solids that must be pumped to the SST. To provide the high efficiency phosphorus removal required to comply with permit TP limits, over 99% TP removal efficiency is required in the wastewater chemical precipitation/clarification process used in this treatment system. This phosphorus removal process is anticipated to result in the production of additional sludge solids that will be mixed with the waste activated sludge biological solids. The total alum sludge/biological sludge mixture to be produced by the combined activated sludge and chemical phosphorus removal process is calculated as follows:

- 1) Calculate biological solids from BOD removal;

$$\text{Biological Solids} = 0.60 \text{ \#Solids/\#BOD}(800 \text{ mg/L}) = 480 \text{ mg/L}$$

- 2) Calculate organic P in biological solids, assuming organic P in biological solids removed is 2% by weight with biological phosphorus removal;

$$\text{P in biological solids} = 480 \text{ mg/L} \times 0.02 = 9.6 \text{ mg/L}$$

- 3) Calculate P removed by alum precipitation with average influent TP $\leq 16.0 \text{ mg/L}$ in the pretreated wastewater discharged from the DAF cell.

$$\text{P removed by alum} = \text{P in (influent - biological solids - effluent)}$$

$$= (16 - 9.6 - 0.1) = 6.3 \text{ mg/L} \leq 7.0 \text{ mg/L}$$


- 4) Assume an alum dose of 12 mg Alum/L : 1 mg P/L will be necessary to meet the very high efficiency phosphorus removal requirements specified by the discharge permit:

$$\begin{aligned} \text{Alum dosage} &= 7 \text{ mg P/L} \times 12 \text{ mg Alum/mg P} &= 84 \text{ mg/L} \leq 100 \text{ mg/L} \\ \text{Al dosage} &= 100 \text{ mg/L} (2 \times 27/594) &\leq 10 \text{ mg/L} \end{aligned}$$

- 5) Calculate AlPO_4 precipitate

$$\begin{aligned} \text{AlPO}_4 \text{ precipitate} &= \frac{(\text{P removed by alum})(\text{Mol. wt. of AlPO}_4)}{\text{Mol. wt. of P}} \\ &= \frac{(7.0 \text{ mg/L})[(27 + 31 + (16 \times 4)]}{31} \\ &= 27.5 \text{ mg/L} \end{aligned}$$

- 6) Calculate unused alum



1 mole Alum/2 mole P

$$\begin{aligned} \text{Alum used} &= \frac{(\text{P removed}) (\text{Mol. wt. of alum})}{\text{Mol. wt. of P}} \\ &= \frac{(7.0 \text{ mg/L})(594)}{2 \times 31} \\ &= 67 \text{ mg/L} \end{aligned}$$

$$\begin{aligned} \text{Unused Alum} &= \text{Alum dosed} - \text{Alum used} \\ &= 100 \text{ mg/L} - 67 \text{ mg/L} \\ &= 33 \text{ mg/L} \end{aligned}$$

- 7) Calculate $\text{Al}(\text{OH})_3$ precipitate



1 mole Alum/2 mole $\text{Al}(\text{OH})_3$

$$\text{Al}(\text{OH})_3 \text{ precipitate} = \frac{(\text{unused Alum}) (\text{Mol. wt. of Al}(\text{OH})_3)}{\text{Mol. wt. of alum}}$$

$$= \frac{(33 \text{ mg/L}) (2 \times [(27 + (17 \times 3)])}{594}$$

$$= 8.6 \text{ mg/L} \leq 9.0 \text{ mg/L}$$

8) Calculate chemical and biological sludge production

$$\text{Total Sludge mg/L} = 480 \text{ mg/L} + 27.5 \text{ mg/L} + 9.0 \text{ mg/L} = 516.5 \text{ mg/L} \leq 525 \text{ mg/L}$$

$$\text{Chemical Sludge mg/L} = 27.5 \text{ mg/L ALPO}_4 + 9.0 \text{ mg/L Al(OH)}_3 = 36.5 \text{ mg/L} \leq 40 \text{ mg/L}$$

9) Calculate volume of sludge produced assuming 1.00% solids in return sludge from the final clarifier:

$$\text{Dry solids produced} = (525 \text{ mg/L})(2.00 \text{ MGD})(8.34) = 8,757\#/day$$

$$\leq 9,000\#/day$$

$$\text{Sludge Volume} = \frac{9,000\#/day}{(0.01)8.34}$$

$$\leq 110,000 \text{ gpd @ 1.0\% solids concentration}$$

The total maximum dry weight and volume of waste sludge to be produced by the treatment system is therefore calculated to be approximately 110,000 gpd @ 75 gpm over 24 hours/day; or, 150 gpm over 12 hours/day assuming a 1.0% waste sludge solids concentration with aluminum sulfate dosage.

R. WASTE ACTIVATED SLUDGE STORAGE TANKS (Existing & New)

1. General Description

- a. The two existing Waste Activated Sludge (WAS) Storage Tanks (SST) will continue to be used for aerobic digestion, gravity thickening, and decanting of WAS solids generated by the BNR treatment process.
- b. Accumulated sludge solids contained in the old, out of service, anaerobic lagoon will be gradually pumped into the two existing Sludge Storage Tanks #1 and #2 for mixing and aerobic digestion with WAS prior to dewatering and disposal with WAS.

- c. Aerobically digested and gravity thickened sludge solids will be pumped from the SST's to the existing Belt Press and/or the new Screw Press for mechanical dewatering prior to hauling off site for ultimate disposal.

2. Sludge Storage Tank Design

- a. Two existing 37 ft. dia. X 13 ft. maximum liquid depth, 0.100 MG (13.4 x 10³ft³) volume above grade bolted, glass coated, carbon steel tanks will continue to be used as SST #1 and SST #2 for WAS digestion, storage and gravity thickening.
- b. WAS will be pumped from the RAS suction lines from the two Final Clarifiers into the SSTs.
- c. Accumulated solids will also be pumped at a low flow rate and daily volume from the old unused anaerobic lagoon into SST #1 and SST #2 for mixing and disposal with WAS.
- d. A floating pipe, manual operated, decanting system is provided in each existing SST for drawing off clarified decant liquid from the surface of the SST at the end of gravity sludge thickening periods.
- e. Gravity thickened sludge will normally be pumped from the bottom of SST #1 and SST #2 to the existing Belt Press or the new Screw Press Sludge Dewatering System.

3. Sludge Storage Tank Aeration and Mixing Equipment Design

- a. Evaluate Mixing Requirements in the Sludge Storage Tanks:
 - 1) SST #1 and SST #2
 - a) One existing 15 HP floating surface aerator is provided in each SST #1 and SST #2 tank for biomass sludge mixing and aeration.
 - b) HP required for mixing ≥ 60 HP/MG
 - c) HP/MG = 15 HP/0.10 MG = 150 HP/MG > 60 HP/MG
- b. Evaluate Oxygen Transfer Requirements in the Sludge Storage Tanks:
 - 1) Assume 0.10#O₂/#BOD is required in the aerobic sludge digester tanks based on the average BNR process BOD loading

$$AOTR = \frac{(0.10\#O_2/\#BOD)(10,000\#BOD/day)}{24} = 42\#O_2/hr \leq 45\#O_2/hr \text{ total}$$

- 2) Oxygen transfer capacity is provided in each SST by an existing floating surface aerator system.
- 3) The maximum oxygen transfer rate provided in each SST by operation of the existing 15 HP floating surface aerator = 20#O₂/hr (AOTR).

S. CLARIFIER SCUM PUMP STATION (Existing)

1. General Description

- a. One existing Scum Pump Station is provided for collection of scum skimmings removed from each of the two Final Clarifiers.
- b. Each Final Clarifier has a gravity scum discharge line that discharges into the Scum Pump Station Wet Well.
- c. Scum liquid is automatically pumped from the Scum Pump Station through an existing force main into existing Reactor #2A or through a new force main into the new Sludge Storage Tank.

2. Design Assumptions

- a. Scum Flow Volumes and Rates
 - 1) Design average scum volume ≤ 20,000 gpd
 - 2) Peak scum volume ≤ 100,000 gpd
- b. Wastewater Pumping Requirements
 - 1) Design average discharge flow rate = 100 gpm with one scum pump in operation
 - 2) Design peak discharge flow rate = 200 gpm with two scum pumps in operation

3. Pump Selection

- a. Two constant speed drive submersible sewage pumps are to be provided each rated at 100 gpm @ 40 feet total head with a 4" PVC scum force main.
- b. Operation of one pump is required to pump the design average flow rate = 100 gpm.
- c. Operation of two pumps in parallel is required to pump the peak discharge flow rate = 200 gpm.

- d. The second pump is provided as an installed standby. Automatic Lead and Standby pump operation with automatic pump sequence alternator is provided.
- e. Both pumps will be provided with automatic on-off liquid level controls for the Scum Pump Station wet well.

T. EFFLUENT FLOW METER (Existing)

1. One existing 9" throat x 30" max. liquid depth Parshall Flume Flow Meter with a maximum flow capacity = 2,400 gpm = 3.4 MGD is provided to measure the total flow discharging from the existing chlorine contact basin.
2. One existing flow indicating, recording, totalizing flow meter is provided with the Parshall Flume. The flow meter uses a 30-day continuous indicating-recording strip chart located in the existing Pretreatment Building control room.
3. A staff gauge is also provided for manual flow measurement if the automatic Parshall Flume flow meter is out-of-service. The staff gauge can also be used to check calibration of the automatic flow meter.

U. CHEMICAL STORAGE-FEED EQUIPMENT FOR ACTIVATED SLUDGE PROCESS (Existing)

1. Cationic polymer flocculant solution mixing, storage and pumping equipment is provided for dosing settling aid polymer solution into the final clarifier influent mixed liquor when required.
 - a. One existing 1,600 gallon fiberglass tank with a 2.0 HP mixer is provided for make-up and storage of cationic polymer flocculant solution. Up to 133# of liquid cationic polymer can be weighed and manually added to the 1,600 gallon tank two times/day, filled with water and mixed to make up a 1% by weight cationic polymer solution to be pumped to the injection point in the clarifier influent lines.
 - b. Two existing cationic polymer solution pumps are provided each rated @ 90 to 900 gphr of solution. Operation of one pump @ 90 to 900 gphr @ 60 psi can provide a dosage capacity of 5 to 50 mg/L in the maximum clarifier influent mixed liquor inflow of 4.00 MGD = 2.00 MGD plus 100% sludge recycle rate. Lower dosage rates can be pumped if a lower solution strength is made up in the mix tank. The second polymer solution pump is provided as an installed standby.
2. Magnesium hydroxide (MgOH) solution storage, mixing and pumping equipment is provided for dosing MgOH solution into the activated sludge treatment process influent flow for mixed liquor alkalinity and pH control in the biological nitrification process.

- a. One existing 5,000 gallon bulk storage tank is provided for storage of commercially purchased pre-mixed 62% strength magnesium hydroxide solution. Magnesium hydroxide solution is dosed into the DAF Cell Effluent Pump Station Wet Well prior to pumping of pretreated wastewater to FEB Anoxic Reactor #1A in order to maintain mixed liquor pH above 6.8 units in the biological nitrification process by pumping magnesium hydroxide solution into an injection point in Nitrification Reactor #2A.
- b. Two existing magnesium hydroxide (MgOH) solution pumps are provided each rated at 10 - 100 gphr @ 60 psi to dose MgOH solution into the 2.00 MGD design flow volume. One pump @ 10 - 100 gphr will inject MgOH at a rate of over 18,000#/day $\geq 1,000$ mg/L (dry basis). The normal MgOH dosage requirement is expected to be between 10 to 30 gphr or 100 to 300 mg/L (dry basis). A second MgOH pump is provided as an uninstalled standby.

1) Calculated MgOH dosage rate for nitrification of 1,685# of Ammonia Nitrogen @ 7.0# alk/#TKN when biological denitrification is achieved in FEB/Reactors #1A and #1B:

a) $(1,685\# \text{ NH}_3 \text{ -N) nitrified/day} \times 7.0\# \text{ alk/\#TKN}$

$$\leq 12,000\# \text{ alk/day}$$

b) estimated alkalinity available from denitrification of over 83% of the nitrified TKN assuming 3.0# alk/#TKN denitrified,

$$= (1,685\#\text{TKN/day})(0.83)3.0\#\text{alk/\#TKN}$$

$$= 4,200\#\text{alk/day} < 4,000\#\text{alk/day}$$

c) estimated alkalinity available in partially pretreated wastewater = $(200 \text{ mg/L})(8.34)(2.00 \text{ MGD}) \geq 3,000\#\text{day}$

d) estimated alkalinity in the final effluent = $100 \text{ mg/L} = (100 \text{ mg/L})(8.34)(2.00 \text{ MGD}) \geq 1,500\#\text{day}$

e) @ 1.4# CaCO₃ alk/# MgOH solution

$$= \frac{12,000\# - 4,000\# - 3,000\# + 1,500\#}{1.4\# \text{ MgOH/\#alk}}$$

$$= \frac{6,500\#\text{alk/day}}{1.4\#\text{MgOH/\#alk}}$$

$$= 4,642\#\text{MgOH/day} < 5,000\#\text{alk/day}$$

- f) @ 62% maximum MgOH solution strength the MgOH solution volume required per day and solution pumping rate required/hr =

$$\frac{5,000\#/day}{0.62(12.4\#/gal)} = 650 \text{ gpd}$$
$$\leq 30 \text{ gal/hr}$$

vs. 100 gal/hr pumping capacity provided by one MgOH solution pump in operation.

V. CHEMICAL STORAGE-FEED EQUIPMENT FOR PHOSPHORUS REMOVAL (Existing)

1. Coagulant solution storage and pumping equipment is provided for aluminum sulfate or aluminum chloride solution into the mixed liquor flow into the Final Clarifier for phosphorous removal by precipitation in the Final Clarifier.
 - a. For dosage of aluminum sulfate coagulant solution into Clarifier influent mixed liquor flow for phosphorous removal:
 - 1) Maximum chemically treatable total phosphorous concentration in Final Clarifier influent $\leq 16.0 \text{ mg/L}$; 267#/day @ 2.00 MGD.
 - 2) Assume $\leq 12 \text{ mg/L}$ aluminum sulfate solution per mg/L phosphorous is required to reduce final effluent TP to $< 0.10 \text{ mg/L}$

$$\text{Maximum alum. dosage} \leq 16.0 \text{ mg/L}(12 \text{ mg/L}) \leq 200 \text{ mg/L} = 3,336\# \text{ alum/day}$$

- 3) Calculated aluminum sulfate solution dosage

$$= \frac{3,336\#/day}{5.4\#/gal^{(1)}} \leq 617 \text{ gpd} \leq 25 \text{ gphr}$$

(1) 50% liquid alum solution @ 5.4# alum/gal

- 4) The existing 4,500 gallon fiberglass bulk tank will continue to be used for storage of 40% strength aluminum sulfate solution. The bulk tank is located in the existing Wastewater Pretreatment Equipment Building. Aluminum sulfate solution can be pumped into the Final Clarifier Floc Tank upstream of each Final Clarifier.

- 5) Two existing coagulant solution pumps with manual stroke drive are provided each rated at 3 to 30 gphr @ 60 psi to dose coagulant solution into the 2.00 MGD design flow rate. One pump @ 3 to 30 gphr can inject aluminum sulfate or aluminum chloride solution at a rate of over 3,500#/day \geq 200 mg/L (dry basis). The normal alum dosage requirement is expected to be between 10 to 20 gphr or 75 to 150 mg/L (dry basis). A second alum pump is provided for parallel operation and as an installed standby

W. CHEMICAL STORAGE-FEED EQUIPMENT FOR FINAL EFFLUENT PH CONTROL (Existing)

1. The following equipment is provided for storage and pumping chemical solution necessary for final effluent pH control:
 - a. For pH adjustment of effluent from UV contact basin to maintain final effluent pH above 6.0 units:
 - 1) Two existing 2,500 gallon fiberglass tank is provided for bulk storage of magnesium hydroxide.
 - 2) One existing magnesium hydroxide pump with variable speed drive is provided to inject magnesium hydroxide into DAF Effluent Pump Station wet well.

X. EXPECTED FINAL EFFLUENT QUALITY AND FINAL EFFLUENT NPDES PERMIT LIMITATIONS

1. After treatment by flow equalization, dissolved air flotation first stage pretreatment; 7 day flow equalization and two stage activated sludge biological treatment; final clarification; and UV disinfection, the following effluent quality is expected under normal operating conditions:

| Parameter | Expected Effluent Quality | Effluent Limitations | | | | | | |
|-----------------------|---------------------------|--|-----------|-------|--------------------------|--------------------------|-------------|------------|
| | | Load | | | Concentrations | | | |
| | | Daily Average | Daily Max | Units | Daily Avg ⁽¹⁾ | Daily Max ⁽¹⁾ | Max Instant | Units |
| BOD ₅ | < 5 mg/L | 114.0 | 227.0 | #/day | 6.8 | 13.6 | --- | mg/L |
| TSS | < 5 mg/L | 152.0 | 228.0 | #/day | 9.1 | 13.6 | --- | mg/L |
| O&G | < 2 mg/L | 68.0 | 99.0 | #/day | 4.0 | 5.9 | --- | mg/L |
| Total Phosphorus | < 0.30 mg/L | 15.0 | 23.0 | #/day | 0.90 | 1.37 | --- | mg/L |
| Ammonia-N (Apr-Oct) | < 1 mg/L | 20.5 | 32.0 | #/day | 1.22 | 1.91 | --- | mg/L |
| Ammonia-N (Nov-Mar) | < 2 mg/L | 35 | 70.0 | #/day | 2.09 | 4.2 | --- | mg/L |
| Enterococcus Bacteria | < 30 | --- | --- | #/day | 33.0 | --- | --- | col/100 ml |
| pH | 6.7 – 6.9 | The pH shall be between 6.0 S.U. and 9.0 S.U. at all times | | | | | | S.U. |

⁽¹⁾@ 2.00 MG based on Load Limit