



June 18, 2020

Mr. John Rebar  
Division of Water Resources  
State of Delaware DNREC  
89 Kings Highway  
Dover, DE 19901

**RE: Draft Construction and Operation Permits**

Dear Mr. Rebar,

Please find below comments from Mountaire regarding the draft Construction Permit #359191-05 and the draft Operations Permit #359191-06.

**Draft Construction Permit #359191-05**

1. Page 4 – Future dryer and Class A solids should be removed.
2. Page 5 #2 – DAF Cell 1B – should be 2400 gpm, not 1800 gpm. DAF Cell 1B can operate either in parallel or independently. The DAFs will operate 24 hours/day 6 to 7 days a week.
3. Page 7 – There is no mention of the UV system which is included in both the process flow diagram on page 4 and the Final Design Report.
4. Page 7 - #11 – There will be two (2) or three (3) screw presses installed for sludge dewatering depending on size and brand chosen.
5. Page 9 #3 – There is only one (1) new lagoon and it will be synthetically lined.

**Draft Operations Permit #359191-06**

1. Page 6 – Future dryer Class A solids should be removed.

Please contact me with any questions at 302-934-4052.

Sincerely,

Tanya Rogers-Vickers  
Director of Environmental Compliance



**Mountaire Farms Inc.**

*“We measure quality by how well we service our internal and external customers”*